

## **Access Compliance Report Public Rights-of-Way** (Curb Ramps)



Intersection ID: 10904 Main Street: ALLEGHANY ST **Cross Street: ASHLEY RD** Location: SW **ADA ID: 971A1FCBEC98** Ramp Type: PerpDiag Initial Pass/Fail: Fail **Overall Compliance: No** Severity Score: 13.75

**Codes/Mitigation Info/Possible Solution** 

Signal

Signal

## Field Measurements/Component Compliance



**ASHLEY RD** Street 1 Name Stop Condition-Street 2 Street 2 Name **ALLEGHANY ST** Stop Condition-Street 1

Possible Solutions: Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent. Surveyor Notes: N/A PROW/ADA: Not Found, R304.2.2, R304.5.3

Total Cost: 3200.00

Field Measurements/Component Compliance					
Compliance Description		Data	Compliance Description		Data
N/A	Ramp Length (in)	60.0	No	Ramp Slope (%)	9.0
Yes	Ramp Width (in)	50.0	No	Ramp XSlope (%)	3.0
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	Yes
	X Walk 1 Direction	To E		X Walk 2 Direction	To N
N/A	X Walk 1 Width (in)	105.0	N/A	X Walk 2 Width (in)	109.0
	X Walk 1 Slope (%)	3.2		X Walk 2 Slope (%)	4.1
	X Walk 1 X Slope (%)	2.0		X Walk 2 X Slope (%)	4.2
N/A	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	Yes
	Road Slope (%)	1.2	N/A	Clear Space?	N/A
	Road X Slope (%)	4.4	N/A	Clear Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good
W.		,	•	, ,	





