


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 20239	Main Street: BROWNFIELD_TRAIL_CT	Cross Street: GRIERS_FORK_DR	Location: SE
ADA ID: 9759B1BD118F	Ramp Type: BlendTrans1	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 10	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		N/A	Ramp Length (in)	44.0	Yes	BlendTrans Slope (%)	4.0
			No	Ramp Width (in)	38.0	No	BlendTrans XSlope (%)	2.5
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
Surveyor Notes:		N/A	N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
			N/A	Shared Landing?	N/A			
PROW/ADA:		R304.5.1, R304.5.3	N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
			N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
			N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
				X Walk 1 Direction	To N		X Walk 2 Direction	To W
				X Walk 1 Width (in)	N/A		X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	2.2		X Walk 2 Slope (%)	1.4
				X Walk 1 X Slope (%)	1.5		X Walk 2 X Slope (%)	1.6
Street 1 Name		BROWNFIELD TRAIL CT	N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
Stop Condition-Street 1		StopSign		Road Slope (%)	3.7		Clear Space?	N/A
Street 2 Name		GRIERS FORK DR		Road X Slope (%)	1.6	N/A	Clear Space to XWalk (in)	N/A
Stop Condition-Street 2		None	N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
				Obstruction Type			Storm Grate/Utility Type	
					N/A			N/A
						Yes	Surface Condition? (G/P)	Good
						N/A	Curb Slope (%)	2.8

Possible Solutions:

**Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.**

Surveyor Notes:

**N/A**

PROW/ADA:

**R304.5.1, R304.5.3**

Total Cost: \$ 3200.00

Street 1 Name **BROWNFIELD TRAIL CT**  
 Stop Condition-Street 1 **StopSign**  
 Street 2 Name **GRIERS FORK DR**  
 Stop Condition-Street 2 **None**

