

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: N/A Main Street: LAWYERS RD **Cross Street: COVINGTON COMMONS DR** Location: NW ADA ID: 986E70A06C36 Ramp Type: PerpDiag Initial Pass/Fail: Fail **Overall Compliance: No Severity Score:** 25

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Street 1 Name Stop Condition-Street 2 Street 2 Name **COVINGTON COMMONS DR** Stop Condition-Street 1

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Possible Solutions:

LAWYERS RD

None

StopSign

Surveyor Notes: N/A PROW/ADA: Not Found, R304.2.2

Total Cost: 3200.00

Compliance Description Da		Data	Compliance Description		Data
N/A	Ramp Length (in)	47.0	No	Ramp Slope (%)	13.9
Yes	Ramp Width (in)	48.0	Yes	Ramp XSlope (%)	0.4
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	1.0	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
	X Walk 1 Direction	To SW		X Walk 2 Direction	To SE
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	1.4		X Walk 2 Slope (%)	1.0
	X Walk 1 X Slope (%)	1.5		X Walk 2 X Slope (%)	1.0
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	1.2	N/A	Clear Space?	N/A
	Road X Slope (%)	1.5	N/A	Clear Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good





