

# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 9733	Main Street: LARRY_DR	Cross Street: TUCKASEEGEE_RD	Location: SE
ADA ID: 994ED776CB08	Ramp Type: Directional1	Initial Pass/Fail: Pass	Overall Compliance: No
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Detectable Warning System. Grind Gutter Lip.**

Surveyor Notes:

**NO CURB. DWS OS MEASURED TO ASP**

PROW/ADA:

**R305.1.4, R305.2, R302.7.2**

Street 1 Name	<b>TUCKASEEGEE RD</b>
Stop Condition-Street 1	<b>None</b>
Street 2 Name	<b>N/A</b>
Stop Condition-Street 2	<b>N/A</b>

Total Cost: \$ 1000.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	77.0	Yes	Grade Break?	Yes
Yes	Ramp Width (in)	59.0	Yes	Grade Break Slope (%)	3.8
Yes	Ramp Slope (%)	0.3	Yes	Grade Break XSlope (%)	0.3
Yes	Ramp XSlope (%)	0.2			
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
Yes	Landing Length (in)	51.5	Yes	DWS Provided?	Yes
Yes	Landing Width (in)	59.0	Yes	DWS Contrast?	Yes
Yes	Landing Slope (%)	0.4	Yes	DWS Length (in)	24.5
Yes	Landing X Slope (%)	1.2	No	DWS Full Width?	No
N/A	Landing Curb? (Y/N)	No	No	DWS Offset LT (in)	7.0
N/A	Shared Landing?	No	Yes	DWS Offset RT (in)	36.0
Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	4.5
No	Gutter Lip Ht (in)	0.5	Yes	Gutter X Slope (%)	0.6
N/A	Painted X Walk1?	No		Road Slope (%)	0.8
	X Walk 1 Direction	To N		Road X Slope (%)	0.4
	X Walk 1 Width (in)	N/A		Clear Space?	Yes
	X Walk 1 Slope (%)	0.8	N/A	Clear Space to XWalk (in)	N/A
	X Walk 1 X Slope (%)	0.4	Yes	Storm Grate/Utility Hazard?	No
N/A	Ramp inside XWalk1?	N/A		Storm Grate/Utility Type	
Yes	Any Obstructions?	No			N/A
	Obstruction Type		Yes	Surface Condition? (G/P)	Good
			N/A	Curb Slope (%)	N/A

