


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10023283	Main Street: CHEROKEE_RD	Cross Street: N/A	Location:	E
ADA ID: 9C71BDDA2671	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance											
	Possible Solutions:		Compliance			Description			Data					
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)		179.0		No	Ramp Slope (%)		12.3			
			Yes	Ramp Width (in)		111.0		Yes	Ramp XSlope (%)		1.5			
			N/A	Flare Type LT		N/A		N/A	Flare Type RT		N/A			
			N/A	Flare Slope LT (%)		N/A		N/A	Flare Slope RT (%)		N/A			
			N/A	Flare Traversable LT?		N/A		N/A	Flare Traversable RT?		N/A			
			N/A	Landing Length (in)		N/A		N/A	DWS Provided?		N/A			
			N/A	Landing Width (in)		N/A		N/A	DWS Contrast?		N/A			
			N/A	Landing Slope (%)		N/A		N/A	DWS Length (in)		N/A			
			N/A	Landing X Slope (%)		N/A		N/A	DWS Full Width?		N/A			
Surveyor Notes:		N/A			N/A	Landing Curb? (Y/N)		N/A		N/A	DWS Offset (in)		N/A	
PROW/ADA:		Not Found, R304.2.2			N/A	Shared Landing?		N/A						
					N/A	Gutter Ponding?		N/A		N/A	Gutter Slope (%)		N/A	
					N/A	Gutter Lip Ht (in)		N/A		N/A	Gutter X Slope (%)		N/A	
					N/A	Painted X Walk1?		Yes		N/A	Painted X Walk2?		N/A	
						X Walk 1 Direction		To W			X Walk 2 Direction		N/A	
					N/A	X Walk 1 Width (in)		149.0		N/A	X Walk 2 Width (in)		N/A	
						X Walk 1 Slope (%)		3.6			X Walk 2 Slope (%)		N/A	
						X Walk 1 X Slope (%)		2.0			X Walk 2 X Slope (%)		N/A	
					N/A	Ramp inside XWalk1?		Yes		N/A	Ramp inside XWalk2?		N/A	
						Road Slope (%)		N/A		N/A	Clear Space?		N/A	
						Road X Slope (%)		N/A		N/A	Clear Space to XWalk (in)		N/A	
					N/A	Any Obstructions?		N/A		N/A	Storm Grate/Utility Hazard?		N/A	
						Obstruction Type					Storm Grate/Utility Type			
								N/A					N/A	
										Yes	Surface Condition? (G/P)		Good	
Street 1 Name		CHEROKEE RD												
Stop Condition-Street 2		None												
Street 2 Name		N/A												
Stop Condition-Street 1		N/A												
Total Cost:		\$ 1850.00												

