

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 7448	Main Street: ROCKY_RIVER_RD	Cross Street: GRIER_RD	Location: W
ADA ID: 9D5307C3E7F9	Ramp Type: IslandPerp	Initial Pass/Fail: Pass	Overall Compliance: No
Severity Score: 22.5			
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

**Remove & Replace Entire Ramp.
Gutter Ponding Observed. Relocate
Obstruction.**

Surveyor Notes:

N/A

PROW/ADA:

**R304.2.1, R305.1.4, R302.7, R302.3,
R402.2**

Street 1 Name	GRIER RD
Stop Condition-Street 2	YieldSign
Street 2 Name	N/A
Stop Condition-Street 1	N/A

Total Cost: \$ 4900.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	57.0	Yes	Ramp Slope (%)	5.7
Yes	Ramp Width (in)	48.0	Yes	Ramp XSlope (%)	1.9
N/A	Flare Type LT	Sloped	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	6.2	Yes	Flare Slope RT (%)	7.5
N/A	Flare Traversable LT?	Yes	N/A	Flare Traversable RT?	Yes
No	Landing Length (in)	42.0	Yes	DWS Provided?	Yes
Yes	Landing Width (in)	48.0	Yes	DWS Contrast?	Yes
Yes	Landing Slope (%)	1.5	Yes	DWS Length (in)	29.0
Yes	Landing X Slope (%)	0.1	No	DWS Full Width?	No
N/A	Landing Curb? (Y/N)	No	Yes	DWS Offset (in)	0.0
N/A	Shared Landing?	Yes			
No	Gutter Ponding?	Yes	Yes	Gutter Slope (%)	1.0
Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	0.5
N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	N/A
	X Walk 1 Direction	To NW		X Walk 2 Direction	N/A
N/A	X Walk 1 Width (in)	88.0	N/A	X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	0.5		X Walk 2 Slope (%)	N/A
	X Walk 1 X Slope (%)	0.8		X Walk 2 X Slope (%)	N/A
Yes	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	N/A	N/A	Clear Space?	Yes
	Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
No	Any Obstructions?	Yes	No	Storm Grate/Utility Hazard?	No
	Obstruction Type			Storm Grate/Utility Type	
	XWALK POST LNDG				N/A
			Yes	Surface Condition? (G/P)	Good

