


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 13518		Main Street: COMMONWEALTH_AV		Cross Street: ST_JULIEN_ST		Location: W									
ADA ID: 9D72FFFA01E3		Ramp Type: Directional1		Initial Pass/Fail: Pass		Overall Compliance: Yes		Severity Score: 0							
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance											
<div></div> <div>Street 1 NameST JULIEN ST</div> <div>Stop Condition-Street 1None</div> <div>Street 2 NameN/A</div> <div>Stop Condition-Street 2N/A</div>				Possible Solutions:		N/A									
				Surveyor Notes:		N/A									
				PROW/ADA:		N/A									
				Total Cost:		\$ 0.00									
				Compliance		Description		Data		Compliance		Description		Data	
				N/A		Ramp Length (in)		75.5		Yes		Grade Break?		Yes	
				Yes		Ramp Width (in)		50.0		Yes		Grade Break Slope (%)		1.9	
				Yes		Ramp Slope (%)		3.1		Yes		Grade Break XSlope (%)		1.4	
				Yes		Ramp XSlope (%)		0.5							
				Yes		Flare Type LT		N/A		Yes		Flare Type RT		N/A	
N/A		Flare Slope LT (%)		N/A		N/A		Flare Slope RT (%)		N/A					
N/A		Flare Traversable LT?		No		N/A		Flare Traversable RT?		No					
Yes		Landing Length (in)		94.0		Yes		DWS Provided?		Yes					
Yes		Landing Width (in)		68.0		Yes		DWS Contrast?		Yes					
Yes		Landing Slope (%)		1.1		Yes		DWS Length (in)		24.0					
Yes		Landing X Slope (%)		0.3		Yes		DWS Full Width?		Yes					
N/A		Landing Curb? (Y/N)		No		Yes		DWS Offset LT (in)		17.0					
N/A		Shared Landing?		No		Yes		DWS Offset RT (in)		1.5					
Yes		Gutter Ponding?		No		Yes		Gutter Slope (%)		0.2					
Yes		Gutter Lip Ht (in)		0.0		Yes		Gutter X Slope (%)		1.5					
N/A		Painted X Walk1?		No				Road Slope (%)		3.5					
		X Walk 1 Direction		To SE				Road X Slope (%)		1.7					
		X Walk 1 Width (in)		N/A				Clear Space?		Yes					
		X Walk 1 Slope (%)		3.5		N/A		Clear Space to XWalk (in)		N/A					
		X Walk 1 X Slope (%)		1.7		Yes		Storm Grate/Utility Hazard?		No					
N/A		Ramp inside XWalk1?		N/A				Storm Grate/Utility Type							
Yes		Any Obstructions?		No						N/A					
		Obstruction Type				Yes		Surface Condition? (G/P)		Good					
						N/A		Yes		Curb Slope (%)		2.2			

