

# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 10317	Main Street: E_32ND_ST	Cross Street: N_DAVIDSON_ST	Location: S
ADA ID: A053A78B0607	Ramp Type: Directional1	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 8.75	

#### Codes/Mitigation Info/Possible Solution

#### Field Measurements/Component Compliance



Possible Solutions:

**Remove & Replace Entire Ramp.**

Surveyor Notes:

**N/A**

PROW/ADA:

**R304.5.1**

Total Cost:

\$ 1600.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	81.0	N/A	Grade Break?	N/A
No	Ramp Width (in)	47.0	N/A	Grade Break Slope (%)	0.0
Yes	Ramp Slope (%)	5.2	N/A	Grade Break XSlope (%)	0.0
Yes	Ramp XSlope (%)	1.7			
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	0.0
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	0.0	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	0.0	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	0.0	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	0.0	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset LT (in)	N/A
N/A	Shared Landing?	N/A	N/A	DWS Offset RT (in)	N/A
N/A	Gutter Ponding?	0.0	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	0.0	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	Yes		Road Slope (%)	2.1
	X Walk 1 Direction	To NE		Road X Slope (%)	0.5
	X Walk 1 Width (in)	108.0		Clear Space?	N/A
	X Walk 1 Slope (%)	2.1	N/A	Clear Space to XWalk (in)	N/A
	X Walk 1 X Slope (%)	0.5	N/A	Storm Grate/Utility Hazard?	N/A
N/A	Ramp inside XWalk1?	Yes		Storm Grate/Utility Type	
N/A	Any Obstructions?	N/A			N/A
	Obstruction Type		Yes	Surface Condition? (G/P)	Good
			N/A	Curb Slope (%)	21.1

Street 1 Name	E 32ND ST
Stop Condition-Street 1	StopSign
Street 2 Name	N/A
Stop Condition-Street 2	N/A

