

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10032566	Main Street: N_GRAHAM_ST	Cross Street: N/A	Location: S
ADA ID: A13EDF2E3D78	Ramp Type: Para	Initial Pass/Fail: Pass	Overall Compliance: Yes
		Severity Score: 0	

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Possible Solutions:

N/A

Surveyor Notes:

N/A

PROW/ADA:

N/A

Total Cost:

\$ 0.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length LT (in)	48.8	N/A	Ramp Length RT (in)	48.0
Yes	Ramp Width LT (in)	67.0	Yes	Ramp Width RT (in)	66.0
Yes	Ramp Slope LT (%)	5.2	Yes	Ramp Slope RT (%)	3.5
Yes	Ramp XSlope LT (%)	0.8	Yes	Ramp XSlope RT (%)	0.6
Yes	Landing Length (in)	67.0	Yes	DWS Provided?	Yes
Yes	Landing Width (in)	71.0	Yes	DWS Contrast?	Yes
Yes	Landing Slope (%)	0.8	Yes	DWS Length (in)	24.0
Yes	Landing X Slope (%)	0.5	Yes	DWS Full Width?	Yes
N/A	Landing Curb? (Y/N)	Yes	Yes	DWS Offset (in)	0.0
N/A	Shared Landing?	No			
Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	1.7
Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	1.1
N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	N/A
	X Walk 1 Direction	To NW		X Walk 2 Direction	N/A
N/A	X Walk 1 Width (in)	112.0	N/A	X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	2.6		X Walk 2 Slope (%)	N/A
	X Walk 1 X Slope (%)	0.4		X Walk 2 X Slope (%)	N/A
Yes	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	N/A	N/A	Clear Space?	Yes
	Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good
			Compliant	Curb Slope (%)	5.2

