

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 22281 Main Street: SHERBOURNE DR **Cross Street: THORNCLIFF DR** Location: NE ADA ID: A1CFF14153BA Ramp Type: PerpDiag Initial Pass/Fail: Fail **Overall Compliance: No Severity Score:** 37.5

Codes/Mitigation Info/Possible Solution



Street 1 Name Stop Condition-Street 2 Street 2 Name Stop Condition-Street 1

THORNCLIFF DR None SHERBOURNE DR StopSign

Possible Solutions: Remove & Replace Curb Ramp With **Two New Directional Ramps or** Equivalent. Surveyor Notes: N/A PROW/ADA: Not Found, R304.2.2, R304.5.3

Total Cost: 3200.00

Field Measurements/Component Compliance					
Compliance Description		Data	Comp	liance Description	Data
N/A	Ramp Length (in)	40.0	No	Ramp Slope (%)	9.4
Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	11.9
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
	X Walk 1 Direction	To W		X Walk 2 Direction	To S
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	6.9		X Walk 2 Slope (%)	3.8
	X Walk 1 X Slope (%)	7.1		X Walk 2 X Slope (%)	10.1
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	13.5	N/A	Clear Space?	N/A
	Road X Slope (%)	4.6	N/A	Clear Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good
A 30/6					





