


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 47908	Main Street: UNIVERSITY_CITY_BV	Cross Street: E_MALLARD_CREEK_CHURCH_RD	Location: NE
ADA ID: A22CC2EF5BC2	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 22.5	

Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance						
	Possible Solutions:			Compliance	Description	Data	Compliance	Description	Data	
	Remove & Replace Entire Ramp.			N/A	Ramp Length (in)	70.0	No	Ramp Slope (%)	8.6	
				No	Ramp Width (in)	45.0	Yes	Ramp XSlope (%)	2.9	
				N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A	
				N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
				N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A	
				N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A	
				N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A	
				N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
Surveyor Notes:			N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	N/A	
PROW/ADA:			N/A	Shared Landing?	N/A					
Not Found, R304.5.1, R304.2.2			N/A	Gutter Ponding?	N/A	N/A	N/A	Gutter Slope (%)	N/A	
			N/A	Gutter Lip Ht (in)	N/A	N/A	N/A	Gutter X Slope (%)	N/A	
			N/A	Painted X Walk1?	Yes	N/A	N/A	Painted X Walk2?	N/A	
				X Walk 1 Direction	To SW			X Walk 2 Direction	N/A	
			N/A	X Walk 1 Width (in)	111.0	N/A	N/A	X Walk 2 Width (in)	N/A	
				X Walk 1 Slope (%)	0.5			X Walk 2 Slope (%)	N/A	
				X Walk 1 X Slope (%)	3.7			X Walk 2 X Slope (%)	N/A	
			N/A	Ramp inside XWalk1?	Yes	N/A	N/A	Ramp inside XWalk2?	N/A	
				Road Slope (%)	N/A	N/A	N/A	Clear Space?	N/A	
				Road X Slope (%)	N/A	N/A	N/A	Clear Space to XWalk (in)	N/A	
			N/A	Any Obstructions?	N/A	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
				Obstruction Type				Storm Grate/Utility Type		
						N/A			N/A	
						Yes		Surface Condition? (G/P)	Good	
Street 1 Name				MALLARD CREEK CHURCH RD						
Stop Condition-Street 2				Signal						
Street 2 Name				N/A						
Stop Condition-Street 1				N/A						
Total Cost:				\$	1850.00					

