cole

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 2737	Main Street: SKYLINE_DR			Cross Street: VALHALLA_CT				Location:	NW
ADA ID: A2FB02F3515F	Ramp Type: PerpDiag			Initial Pass/Fail: Fail Overall Compliance: No				o Severity Score:	33.75
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance					
		Possible Solutions:		Compliance Description			Data Compliance Description		
		Remove & Replace Curb Ra	amp With	N/A	Ramp Length (in)	50.0	Yes	Ramp Slope (%)	5.5
		Two New Directional Ramps	•	No	Ramp Width (in)	37.5	No	Ramp XSlope (%)	11.5
		Equivalent.		N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
				N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
				N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
VALITALLA CT		Surveyor Notes:		N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
		N/A		N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
				N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
E O				N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
				N/A	Shared Landing?	N/A			
		PROW/ADA:		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
		Not Found, R304.5.1, R304.	53	N/A	Gutter Lip Ht (in)	1.0	N/A	Gutter X Slope (%)	N/A
				N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
	P P	20 20			X Walk 1 Direction	To SW		X Walk 2 Direction	To SE
				N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
Street 1 Name	VALHALLA CT	-			X Walk 1 Slope (%)	14.0		X Walk 2 Slope (%)	3.8
Stop Condition-Street 2	StopSign				X Walk 1 X Slope (%)	1.6		X Walk 2 X Slope (%)	12.4
Street 2 Name	SKYLINE DR			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
Stop Condition-Street 1	None				Road Slope (%)	10.8	N/A	Clear Space?	N/A
					Road X Slope (%)	8.9	N/A	Clear Space to XWalk (in)	N/A
				N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
		Total Cost:	\$ 3200.00		Obstruction Type			Storm Grate/Utility Type	
						N/A			N/A

Yes Surface Condition? (G/P)

Good

