

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 6266Main Street:KATHERINE_KIKER_RDCross Street:MELANIE_THOMPSON_DRLocation:WADA ID: A4BE3BA479FFRamp Type:PerpInitial Pass/Fail:FailOverall Compliance:NoSeverity Score:12.5

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Street 1 Name KATHERINE KIKER RD
Stop Condition-Street 2 StopSign
Street 2 Name N/A
Stop Condition-Street 1 N/A

Possible Solutions:

Remove & Replace Entire Ramp.

Surveyor Notes:

N/A

PROW/ADA:

Not Found, R304.5.3

PROW/ADA: N/A
Not Found, R304.5.3 N/A
N/A
N/A

N/A

Total Cost: \$ 1850.00

Comp	liance Description	Data	Comp	liance	Description	Data
N/A	Ramp Length (in)	46.5	Yes	Ramp	Slope (%)	5.6
Yes	Ramp Width (in)	48.0	No	Ram	XSlope (%)	6.0
N/A	Flare Type LT	N/A	N/A	Flare	Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare	Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare	Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS	Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS	Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS	Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS	Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS	Offset (in)	N/A
N/A	Shared Landing?	N/A				
N/A	Gutter Ponding?	N/A	N/A	Gutte	er Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutte	er X Slope (%)	N/A
N/A	Painted X Walk1?	No	N/A	Paint	ed X Walk2?	N/A
	X Walk 1 Direction	To SE		X Wa	lk 2 Direction	N/A
N/A	X Walk 1 Width (in)	N/A	N/A	X Wa	lk 2 Width (in)	N/A
	X Walk 1 Slope (%)	5.5		X Wa	lk 2 Slope (%)	N/A
	X Walk 1 X Slope (%)	3.8		X Wa	lk 2 X Slope (%)	N/A
N/A	Ramp inside XWalk1?	N/A	N/A	Ram	o inside XWalk2?	N/A
	Road Slope (%)	N/A	N/A	Clear	Space?	N/A
	Road X Slope (%)	N/A	N/A	Clear	Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storn	n Grate/Utility Hazard?	N/A
	Obstruction Type		l	Storn	n Grate/Utility Type	
		N/A				N/A
			Yes	Surfa	ce Condition? (G/P)	Good





