


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 3743		Main Street: EARLSWOOD_DR		Cross Street: WHITE_CASCADE_DR		Location:		NW					
ADA ID: A56C87AF6974		Ramp Type: Directional1		Initial Pass/Fail: Pass		Overall Compliance: No		Severity Score: 0					
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance									
<div></div> <div>Street 1 Name<div>EARLSWOOD DR</div></div> <div>Stop Condition-Street 1<div>StopSign</div></div> <div>Street 2 Name<div>N/A</div></div> <div>Stop Condition-Street 2<div>N/A</div></div>				Possible Solutions:		Compliance		Description		Data			
				Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	36.0		No	Grade Break?	No	
				Remove & Replace Gutter.		Yes	Ramp Width (in)	49.0		N/A	Grade Break Slope (%)	N/A	
						Yes	Ramp Slope (%)	5.4		N/A	Grade Break XSlope (%)	N/A	
						Yes	Ramp XSlope (%)	0.8					
						N/A	Flare Type LT	N/A		N/A	Flare Type RT	N/A	
						N/A	Flare Slope LT (%)	0.7		N/A	Flare Slope RT (%)	5.0	
						N/A	Flare Traversable LT?	No		N/A	Flare Traversable RT?	No	
						No	Landing Length (in)	31.0		Yes	DWS Provided?	Yes	
						Yes	Landing Width (in)	48.0		Yes	DWS Contrast?	Yes	
		Yes	Landing Slope (%)	0.9		Yes	DWS Length (in)	24.5					
		Yes	Landing X Slope (%)	0.2		Yes	DWS Full Width?	Yes					
		N/A	Landing Curb? (Y/N)	N/A		Yes	DWS Offset LT (in)	60.0					
		N/A	Shared Landing?	No		No	DWS Offset RT (in)	8.0					
		Yes	Gutter Ponding?	No		Yes	Gutter Slope (%)	0.8					
		Yes	Gutter Lip Ht (in)	0.0		No	Gutter X Slope (%)	2.7					
		N/A	Painted X Walk1?	No			Road Slope (%)	1.9					
			X Walk 1 Direction	To S			Road X Slope (%)	3.4					
			X Walk 1 Width (in)	N/A			Clear Space?	Yes					
			X Walk 1 Slope (%)	1.9		N/A	Clear Space to XWalk (in)	N/A					
			X Walk 1 X Slope (%)	3.4		Yes	Storm Grate/Utility Hazard?	No					
		N/A	Ramp inside XWalk1?	N/A			Storm Grate/Utility Type						
		Yes	Any Obstructions?	No				N/A					
			Obstruction Type			Yes	Surface Condition? (G/P)	Good					
						N/A	Curb Slope (%)	N/A					
		Total Cost:		\$ 2350.00									

