

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Data

N/A

N/A

N/A

N/A

6.9

0.3

N/A

N/A

N/A

N/A

N/A

N/A

N/A N/A

N/A

N/A

No

N/A

3.0

1.9

N/A N/A

N/A

N/A

N/A

N/A

N/A

Good

18.2

To SE

Clear Space to XWalk (in)

Storm Grate/Utility Hazard?

Storm Grate/Utility Type

Surface Condition? (G/P)

Any Obstruction?

Obstruction Type

Curb Slope (%)

Main Street: N ALEXANDER ST Location: Intersection ID: 12450 Cross Street: E 9TH ST N Ramp Type: Combination2Diag Initial Pass/Fail: Fail **Overall Compliance: No** 0 ADA ID: A6DBED9483A4 **Severity Score:**

Codes/Mitigation Info/Possible Solution


Field Measurements/Component Compliance

3.8 N/A

N/A

N/A

Yes



Street 1 Name StopSign Stop Condition-Street 1 Street 2 Name Stop Condition-Street 2 N ALEXANDER ST Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Surveyor Notes:

N/A


PROW/ADA:

Not Found, R304.5.1, R304.5.1

E 9TH ST StopSign

Compliance Description		Data	Comp	liance Description
N/A	Ramp Length LT (in)	69.0	N/A	Ramp Length RT (in)
No	Ramp Width LT (in)	33.0	N/A	Ramp Width RT (in)
Yes	Ramp Slope LT (%)	5.8	N/A	Ramp Slope RT (%)
Yes	Ramp XSlope LT (%)	0.1	N/A	Ramp XSlope RT (%)
N/A	Ramp Length (in)	26.0	Yes	Ramp Slope (%)
No	Ramp Width (in)	45.0	Yes	Ramp XSlope (%)
N/A	Flare Type LT	N/A	N/A	Flare Type RT
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?
N/A	Landing Length (in)	N/A	N/A	DWS Provided?
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)
N/A	Shared Landing?	N/A		
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?
	X Walk 1 Direction	To SW		X Walk 2 Direction
	X Walk 1 Width (in)	N/A		X Walk 2 Width (in)
	X Walk 1 Slope (%)	1.8		X Walk 2 Slope (%)
	X Walk 1 X Slope (%)	3.1		X Walk 2 X Slope (%)
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?
	Road Slope (%)	0.2		Clear Space?





Total Cost:



3200.00