

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 14555 Main Street: E_PARK_AV Cross Street: PARK_RD Location: **Severity Score:** ADA ID: A7C125F85352 Ramp Type: Directional1 Initial Pass/Fail: Fail **Overall Compliance: No** 1.25

Codes/Mitigation Info/Possible Solution



E PARK AV Street 1 Name Stop Condition-Street 1 StopSign Street 2 Name N/A Stop Condition-Street 2 N/A

Possible Solutions: Remove & Replace Entire Ramp. Surveyor Notes: N/A PROW/ADA: R304.5.3

Total Cost: 1600.00

Field Measurements/Component Compliance					
Compliance Description		Data	Compliance Description		Data
N/A	Ramp Length (in)	96.0	N/A	Grade Break?	N/A
Yes	Ramp Width (in)	58.0	N/A	Grade Break Slope (%)	0.0
Yes	Ramp Slope (%)	8.0	N/A	Grade Break XSlope (%)	0.0
No	Ramp XSlope (%)	2.9			
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	0.0
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	0.0	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	0.0	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	0.0	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	0.0	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset LT (in)	N/A
N/A	Shared Landing?	N/A	N/A	DWS Offset RT (in)	N/A
N/A	Gutter Ponding?	0.0	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	0.0	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	Yes		Road Slope (%)	0.8
	X Walk 1 Direction	To NE		Road X Slope (%)	3.5
	X Walk 1 Width (in)	82.0		Clear Space?	N/A
	X Walk 1 Slope (%)	0.8	N/A	Clear Space to XWalk (in)	N/A
	X Walk 1 X Slope (%)	3.5	N/A	Storm Grate/Utility Hazard?	N/A
N/A	Ramp inside XWalk1?	Yes		Storm Grate/Utility Type	
N/A	Any Obstructions?	N/A			N/A
	Obstruction Type		Yes	Surface Condition? (G/P)	Good
		N/A	N/A	Curb Slope (%)	20.7





