


Access Compliance Report

Public Rights-of-Way (Curb Ramps)

Intersection ID: 19749		Main Street: INGLESIDE_DR		Cross Street: KEELING_PL		Location:		SE					
ADA ID: AA108EB9B9AB		Ramp Type: Directional1		Initial Pass/Fail: Fail		Overall Compliance: No		Severity Score: 1.25					
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance									
 <div>Street 1 Name<div>KEELING PL</div></div> <div>Stop Condition-Street 1<div>StopSign</div></div> <div>Street 2 Name<div>N/A</div></div> <div>Stop Condition-Street 2<div>N/A</div></div>				Possible Solutions:		Compliance		Description		Data			
				Remove & Replace Entire Ramp.		N/A		Ramp Length (in)		66.0		N/A	
						Yes		Ramp Width (in)		56.0		N/A	
						Yes		Ramp Slope (%)		5.0		N/A	
						No		Ramp XSlope (%)		2.4			
						N/A		Flare Type LT		N/A		N/A	
						N/A		Flare Slope LT (%)		N/A		N/A	
						N/A		Flare Traversable LT?		N/A		N/A	
						N/A		Landing Length (in)		0.0		N/A	
						N/A		Landing Width (in)		0.0		N/A	
		N/A		Landing Slope (%)		0.0		N/A					
		N/A		Landing X Slope (%)		0.0		N/A					
		N/A		Landing Curb? (Y/N)		N/A		N/A					
		N/A		Shared Landing?		N/A		N/A					
		N/A		Gutter Ponding?		0.0		N/A					
		N/A		Gutter Lip Ht (in)		0.0		N/A					
		N/A		Painted X Walk1?		No							
				X Walk 1 Direction		To NW							
				X Walk 1 Width (in)		N/A							
				X Walk 1 Slope (%)		5.1		N/A					
				X Walk 1 X Slope (%)		2.3		N/A					
		N/A		Ramp inside XWalk1?		N/A							
		N/A		Any Obstructions?		N/A							
				Obstruction Type									
						Yes		Surface Condition? (G/P)					
						N/A		N/A					
								Curb Slope (%)					
								16.6					