


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10038783	Main Street: STEELE_CREEK_RD	Cross Street: N/A	Location: NW
ADA ID: AB70CCFD7976	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
Severity Score: 22.5			
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	

	Possible Solutions:		Compliance		Description	Data	Compliance		Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		N/A	Ramp Length (in)	64.5	No	Ramp Slope (%)	8.4		
			No	Ramp Width (in)	46.0	No	Ramp XSlope (%)	2.9		
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A		
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A		
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A		
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A		
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A		
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A		
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A		
Surveyor Notes: N/A PROW/ADA: Not Found, R304.5.1, R304.2.2, R304.5.3			N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A		
			N/A	Shared Landing?	N/A					
			N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A		
			N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A		
			N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	No		
				X Walk 1 Direction	To S		X Walk 2 Direction	To SE		
			N/A	X Walk 1 Width (in)	94.0	N/A	X Walk 2 Width (in)	N/A		
				X Walk 1 Slope (%)	2.7		X Walk 2 Slope (%)	1.9		
				X Walk 1 X Slope (%)	4.2		X Walk 2 X Slope (%)	1.7		
			N/A	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A		
Street 1 NameENTRANCE Stop Condition-Street 2StopSign Street 2 NameSTEELE CREEK RD Stop Condition-Street 1None				Road Slope (%)	4.0	N/A	Clear Space?	N/A		
				Road X Slope (%)	6.3	N/A	Clear Space to XWalk (in)	N/A		
			N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A		
				Obstruction Type			Storm Grate/Utility Type			
						N/A		N/A		
						Yes	Surface Condition? (G/P)	Good		
Total Cost:		\$	3200.00							

