

## Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 14873	Main Street: BRIAR_CREEK_RD			Cross Street: E_INDEPENDENCE/BRIAR_CREEK_RA Location:					SE
ADA ID: AC15A560A5C9	Ramp Type: Combination1			Initial Pass/Fail: Fail Overall Complian			nce: No	Severity Score:	46.25
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance					
	1 4 4	Possible Solutions:		Compliance Description		otion Data	Data Compliance Description		
		Remove & Replace	Entire Ramp.	N/A	Ramp Length	LT (in) 62.0	N/A	Ramp Length RT (in)	64.0
				Yes	Ramp Width L	T (in) <b>49.0</b>	Yes	Ramp Width RT (in)	49.0
				Yes	Ramp Slope L	T (%) 3.6	No	Ramp Slope RT (%)	15.4
	T-MA			No	Ramp XSlope	LT (%) 3.3	No	Ramp XSlope RT (%)	2.1
				N/A	Ramp Length	(in) <b>60.0</b>	Yes	Ramp Slope (%)	3.3
				No	Ramp Width (i	n) <b>44.5</b>	No	Ramp XSlope (%)	6.7
		Surveyor Notes:		N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
		LT RP < 5%		N/A	Flare Slope L	Г (%) N/A	N/A	Flare Slope RT (%)	N/A
				N/A	Flare Traversa	able LT? N/A	N/A	Flare Traversable RT?	N/A
				N/A	Landing Lengt	h (in) <b>N/A</b>	N/A	DWS Provided?	N/A
				N/A	Landing Width	(in) <b>N/A</b>	N/A	DWS Contrast?	N/A
		PROW/ADA:		N/A	Landing Slope	(%) N/A	N/A	DWS Length (in)	N/A
		Not Found, R304.5.1, R304.5.3,		N/A	Landing X Slo	pe (%) N/A	N/A	DWS Full Width?	N/A
	R304.3.2		N/A	Landing Curb?	? (Y/N) N/A	N/A	DWS Offset (in)	N/A	
6 1/ / · · · · · · · · ·			N/A	Shared Landin	ng? N/A				
			N/A	Gutter Pondin	g? <b>N/A</b>	N/A	Gutter Slope (%)	N/A	
Street 1 Name	StopSign			N/A	Gutter Lip Ht (	in) N/A	N/A	Gutter X Slope (%)	N/A
Stop Condition-StreenDENCE/BRIAR CREEK RA			N/A	Painted X Wal	k1? Yes	N/A	Painted X Walk2?	N/A	
Street 2 Name	N/A				X Walk 1 Direc	ction To N		X Walk 2 Direction	N/A
Stop Condition-Street 2	N/A				X Walk 1 Widt	h (in) <b>110.0</b>		X Walk 2 Width (in)	N/A
					X Walk 1 Slop	e (%) 3.6		X Walk 2 Slope (%)	N/A
					X Walk 1 X Slo	ope (%) 1.9		X Walk 2 X Slope (%)	N/A
		Total Cost:	\$ 180	0.00 N/A	Ramp inside X	Walk1? Yes	N/A	Ramp inside XWalk2?	N/A
					Road Slope (%	%) <b>N/A</b>		Clear Space?	N/A
					Road X Slope	(%) N/A	N/A	Clear Space to XWalk (in)	N/A
							N/A	Any Obstruction?	N/A
	-				and the			Obstruction Type	
					20				N/A
							N/A	Storm Grate/Utility Hazard?	N/A

N/A Storm Grate/Utility Hazard? N/A Storm Grate/Utility Type N/A Yes Surface Condition? (G/P) Good Curb Slope (%) 12.0



