


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 15785	Main Street: CHEROKEE_PL	Cross Street: COLVILLE_RD	Location: NE
ADA ID: AC9A203E1EA3	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 21.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	72.0	No	Ramp Slope (%)	8.7
			No	Ramp Width (in)	47.0	Yes	Ramp XSlope (%)	1.2
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
Surveyor Notes:	N/A		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
			N/A	Shared Landing?	N/A			
	PROW/ADA:		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
	Not Found, R304.5.1, R304.2.2		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
			N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
				X Walk 1 Direction	To SE		X Walk 2 Direction	N/A
			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	0.8		X Walk 2 Slope (%)	N/A
				X Walk 1 X Slope (%)	2.2		X Walk 2 X Slope (%)	N/A
			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
Street 1 Name		CHEROKEE PL		Road Slope (%)	N/A	N/A	Clear Space?	N/A
Stop Condition-Street 2		StopSign		Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
Street 2 Name		N/A		Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
Stop Condition-Street 1		N/A		Obstruction Type			Storm Grate/Utility Type	
Total Cost:		\$ 1850.00			N/A			N/A
						Yes	Surface Condition? (G/P)	Good

Street 1 Name	CHEROKEE PL
Stop Condition-Street 2	StopSign
Street 2 Name	N/A
Stop Condition-Street 1	N/A

