


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 14455		Main Street: EAST_BV		Cross Street: WINTHROP_AV		Location: S									
ADA ID: B15EFAF20096		Ramp Type: Directional1		Initial Pass/Fail: Pass		Overall Compliance: No		Severity Score: 0							
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance											
<div></div> <div>Possible Solutions: Remove & Replace Landing.</div> <div>Surveyor Notes: LNDG SLOPE NEGATIVE</div> <div>PROW/ADA: R304.2.2-Perp, R304.3.2-Para</div>				Compliance		Description		Data		Compliance		Description		Data	
				N/A	Ramp Length (in)	74.0		Yes	Grade Break?	Yes					
				Yes	Ramp Width (in)	71.0		Yes	Grade Break Slope (%)	3.8					
				Yes	Ramp Slope (%)	5.7		Yes	Grade Break XSlope (%)	1.6					
				Yes	Ramp XSlope (%)	0.8									
				Yes	Flare Type LT	N/A		Yes	Flare Type RT	N/A					
				N/A	Flare Slope LT (%)	N/A		N/A	Flare Slope RT (%)	N/A					
				N/A	Flare Traversable LT?	No		N/A	Flare Traversable RT?	No					
				Yes	Landing Length (in)	68.0		Yes	DWS Provided?	Yes					
				Yes	Landing Width (in)	71.0		Yes	DWS Contrast?	Yes					
				No	Landing Slope (%)	6.3		Yes	DWS Length (in)	24.0					
				Yes	Landing X Slope (%)	0.6		Yes	DWS Full Width?	Yes					
				N/A	Landing Curb? (Y/N)	N/A		Yes	DWS Offset LT (in)	39.0					
				N/A	Shared Landing?	No		Yes	DWS Offset RT (in)	0.0					
				Yes	Gutter Ponding?	No		Yes	Gutter Slope (%)	2.8					
				Yes	Gutter Lip Ht (in)	0.0		Yes	Gutter X Slope (%)	0.3					
				N/A	Painted X Walk1?	Yes			Road Slope (%)	5.0					
					X Walk 1 Direction	To NE			Road X Slope (%)	2.2					
					X Walk 1 Width (in)	110.0			Clear Space?	Yes					
					X Walk 1 Slope (%)	5.0		N/A	Clear Space to XWalk (in)	N/A					
					X Walk 1 X Slope (%)	2.2		Yes	Storm Grate/Utility Hazard?	No					
				Yes	Ramp inside XWalk1?	Yes			Storm Grate/Utility Type						
				Yes	Any Obstructions?	No				N/A					
					Obstruction Type			Yes	Surface Condition? (G/P)	Good					
								N/A	Curb Slope (%)	4.8					
				Total Cost:		\$	500.00								

