


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 47982	Main Street: WHEAT RIDGE RD	Cross Street: SOUTH CREEK RD	Location: SW
ADA ID: B1A31D487229	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 8.75	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		Yes	Ramp Length (in)	47.0
			Yes	Ramp Width (in)	46.0
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Flare Type RT	N/A
			N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable RT?	N/A
			N/A	DWS Provided?	N/A
			N/A	DWS Contrast?	N/A
			N/A	DWS Length (in)	N/A
			N/A	DWS Full Width?	N/A
			N/A	DWS Offset (in)	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter X Slope (%)	N/A
			No	Painted X Walk1?	No
				X Walk 1 Direction	To E
			N/A	X Walk 2 Direction	To N
			N/A	X Walk 1 Width (in)	N/A
			N/A	X Walk 2 Width (in)	N/A
			N/A	X Walk 1 Slope (%)	2.1
			N/A	X Walk 2 Slope (%)	0.8
			N/A	X Walk 1 X Slope (%)	1.1
			N/A	X Walk 2 X Slope (%)	1.0
			N/A	Ramp inside XWalk1?	N/A
			N/A	Ramp inside XWalk2?	N/A
			N/A	Road Slope (%)	1.2
			N/A	Clear Space?	N/A
			N/A	Clear Space to XWalk (in)	N/A
			N/A	Storm Grate/Utility Hazard?	N/A
			N/A	Storm Grate/Utility Type	N/A
			N/A	Surface Condition? (G/P)	Good
Surveyor Notes:					
N/A					
PROW/ADA:					
Not Found, R304.5.1					
Total Cost:		\$ 3200.00			

Street 1 Name	WHEAT RIDGE RD
Stop Condition-Street 2	None
Street 2 Name	SOUTH CREEK RD
Stop Condition-Street 1	StopSign

