


Intersection ID: 27325	Main Street: TILLEY MORRIS RD	Cross Street: N/A	Location:	W
ADA ID: B1B6C3420C44	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 1.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance						
	Possible Solutions:		Remove & Replace Entire Ramp.						
	Surveyor Notes:		N/A						
	PROW/ADA:		Not Found, R304.5.3						
	Street 1 Name	ARDREY KELL RD							
	Stop Condition-Street 2	YieldSign							
	Street 2 Name	N/A							
	Stop Condition-Street 1	N/A							
	Total Cost:		\$ 1850.00						
			Compliance	Description	Data	Compliance	Description	Data	
			N/A	Ramp Length (in)	96.0	Yes	Ramp Slope (%)	8.1	
			Yes	Ramp Width (in)	115.0	No	Ramp XSlope (%)	3.9	
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A	
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A	
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A	
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A	
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
			N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
			N/A	Shared Landing?	N/A				
			N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
			N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	
			N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	N/A	
				X Walk 1 Direction	To S		X Walk 2 Direction	N/A	
			N/A	X Walk 1 Width (in)	112.0	N/A	X Walk 2 Width (in)	N/A	
				X Walk 1 Slope (%)	0.5		X Walk 2 Slope (%)	N/A	
				X Walk 1 X Slope (%)	4.1		X Walk 2 X Slope (%)	N/A	
			N/A	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A	
				Road Slope (%)	N/A	N/A	Clear Space?	N/A	
				Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A	
			N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
				Obstruction Type			Storm Grate/Utility Type		
					N/A			N/A	
						Yes	Surface Condition? (G/P)	Good	

