


Access Compliance Report

Public Rights-of-Way (Curb Ramps)

Intersection ID: 11433	Main Street: CLOVER_HILL_LN	Cross Street: MEADOWCLIFF_DR	Location: NW
ADA ID: B23AC49BC2E6	Ramp Type: Directional1	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 7.5	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance			
	Possible Solutions:		Compliance	Description	Data	
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	232.5	Yes
	Remove & Replace Gutter.		Yes	Ramp Width (in)	60.0	Yes
			Yes	Ramp Slope (%)	6.7	No
			Yes	Ramp XSlope (%)	1.8	
			N/A	Flare Type LT	N/A	N/A
			N/A	Flare Slope LT (%)	N/A	N/A
			N/A	Flare Traversable LT?	N/A	N/A
			Yes	Landing Length (in)	58.5	Yes
			Yes	Landing Width (in)	60.0	Yes
<p>Surveyor Notes:</p> <p>N/A</p> <p>PROW/ADA:</p> <p>Not Found, R304.2.2-Perp, R304.3.2-Para, R304.5.3, R305.1.4, R305.2, R304.5.4</p>			No	Landing Slope (%)	2.1	Yes
			Yes	Landing X Slope (%)	1.1	No
			N/A	Landing Curb? (Y/N)	N/A	Yes
			N/A	Shared Landing?	No	No
			Yes	Gutter Ponding?	No	No
			Yes	Gutter Lip Ht (in)	0.0	No
			N/A	Painted X Walk1?	No	
				X Walk 1 Direction	To S	
				X Walk 1 Width (in)	N/A	
				X Walk 1 Slope (%)	0.6	N/A
<p>Total Cost: \$ 2350.00</p>			3.2	X Walk 1 X Slope (%)	Yes	
			N/A	Ramp inside XWalk1?	N/A	
			Yes	Any Obstructions?	No	N/A
				Obstruction Type		
			Yes	Surface Condition? (G/P)	Good	
			N/A	Curb Slope (%)	10.8	

