


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10015305	Main Street: ACADEMY_ST	Cross Street: N/A	Location: W
ADA ID: B31FBA3950BC	Ramp Type: Perp	Initial Pass/Fail: Pass	Overall Compliance: Yes
		Severity Score: 0	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	N/A		N/A	Ramp Length (in)	98.0
			Yes	Ramp Width (in)	55.0
			N/A	Flare Type LT	Sloped
			N/A	Flare Slope LT (%)	9.8
			N/A	Flare Traversable LT?	Yes
			Yes	Landing Length (in)	60.0
			Yes	Landing Width (in)	60.0
			Yes	Landing Slope (%)	1.5
			Yes	Landing X Slope (%)	0.6
<p>Surveyor Notes:</p> <p>N/A</p>			N/A	Flare Type RT	N/A
			N/A	Flare Slope RT (%)	11.0
			N/A	Flare Traversable RT?	No
			Yes	DWS Provided?	Yes
			Yes	DWS Contrast?	Yes
			Yes	DWS Length (in)	24.0
			Yes	DWS Full Width?	Yes
			N/A	DWS Offset (in)	1.5
			N/A	Shared Landing?	No
			Yes	Gutter Ponding?	No
<p>PROW/ADA:</p> <p>N/A</p>			Yes	Gutter Lip Ht (in)	0.0
			N/A	Painted X Walk1?	No
				X Walk 1 Direction	To E
			N/A	X Walk 1 Width (in)	N/A
				X Walk 1 Slope (%)	0.1
				X Walk 1 X Slope (%)	0.3
			N/A	Ramp inside XWalk1?	N/A
			N/A	Road Slope (%)	N/A
			N/A	Road X Slope (%)	N/A
			Yes	Any Obstructions?	No
Total Cost:		\$ 0.00		Obstruction Type	
			N/A		N/A
			Yes	Surface Condition? (G/P)	Good

