


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10022305	Main Street: CAMBRIDGE_WOODS_CT	Cross Street: N/A	Location: SW
ADA ID: B32F6C699DA8	Ramp Type: Perp	Initial Pass/Fail: Pass	Overall Compliance: No
			Severity Score: 30.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	48.0
	Remove & Replace Gutter.		Yes	Ramp Width (in)	48.0
			N/A	Flare Type LT	Sloped
			N/A	Flare Slope LT (%)	4.2
			N/A	Flare Traversable LT?	Yes
			Yes	Landing Length (in)	48.0
			Yes	Landing Width (in)	48.0
			No	Landing Slope (%)	3.6
			Yes	Landing X Slope (%)	2.9
Surveyor Notes: N/A PROW/ADA: Not Found, R304.2.2-Perp, R304.3.2-Para, R305, R302.7.2, R304.5.4			N/A	Flare Type RT	N/A
			Yes	Flare Slope RT (%)	5.0
			N/A	Flare Traversable RT?	Yes
			No	DWS Provided?	No
			N/A	DWS Contrast?	No
			N/A	DWS Length (in)	N/A
			N/A	DWS Full Width?	No
			N/A	DWS Offset (in)	N/A
			Yes	Gutter Ponding?	No
			No	Gutter Lip Ht (in)	1.0
Total Cost: \$ 2600.00			N/A	Painted X Walk1?	No
				X Walk 1 Direction	To NE
			N/A	X Walk 1 Width (in)	N/A
				X Walk 1 Slope (%)	4.8
				X Walk 1 X Slope (%)	3.1
			N/A	Ramp inside XWalk1?	N/A
				Road Slope (%)	N/A
				Road X Slope (%)	N/A
			Yes	Any Obstructions?	No
				Obstruction Type	
			N/A		N/A
			Yes	Surface Condition? (G/P)	Good

