

Access Compliance Report Public Rights-of-Way (Curb Ramps)



Yes

Surface Condition? (G/P)

Good

			<u> </u>		Leastion				
			Cross Street: ST_ANDREWS_LN				Location:	NE	
ADA ID: B3A615614159 Ramp Type: Perp		Initial Pa	Initial Pass/Fail: Fail Overall Compliance: No				o Severity Score:	22.5	
Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance						
	Possible Solutions:		Compliance Description Data			Compliance Description Data		Data	
1 1 1 2 2 2 2 2	Remove & Replace Entire Ram	р.	N/A	Ramp Length (in)	59.0	No	Ramp Slope (%)	10.5	
Act in the second se		-	No	Ramp Width (in)	36.0	No	Ramp XSlope (%)	3.4	
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A	
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
S S S S S S S S S S S S S S S S S S S	4.2		N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A	
	Surveyor Notes:		N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A	
5. ST_ANDREWS_LIN	N/A		N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A	
	and the second sec		N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
6. Contraction of the second	and a		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
			N/A	Shared Landing?	N/A				
	PROW/ADA:		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
	Not Found, R304.5.1, R304.2.2		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	
and the second second second	R304.5.3		N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A	
	143			X Walk 1 Direction	To S		X Walk 2 Direction	N/A	
			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A	
Street 1 Name ST ANDREWS	LN			X Walk 1 Slope (%)	1.9		X Walk 2 Slope (%)	N/A	
Stop Condition-Street 2 StopS	ign			X Walk 1 X Slope (%)	3.6		X Walk 2 X Slope (%)	N/A	
Street 2 Name	N/A		N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A	
Stop Condition-Street 1	N/A			Road Slope (%)	N/A	N/A	Clear Space?	N/A	
				Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A	
			N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
	Total Cost: \$	1850.00		Obstruction Type			Storm Grate/Utility Type		
					N/A			N/A	