

# Access Compliance Report


## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 2436	Main Street: HIGHLAND_CREEK_PY	Cross Street: CAMBRIDGE_BAY_DR	Location: S
ADA ID: B3CB0EAA8B8D	Ramp Type: PerpDiag	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 0	

#### Codes/Mitigation Info/Possible Solution

#### Field Measurements/Component Compliance



Possible Solutions:

**Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent. Restripe Crosswalk. Gutter Ponding Observed.**

Surveyor Notes:

**N/A**

PROW/ADA:

**R304.2.2-Perp, R304.3.2-Para, R305.2, R207.1, R302.7**

Total Cost: \$ 3900.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	86.0	Yes	Ramp Slope (%)	6.2
Yes	Ramp Width (in)	48.0	Yes	Ramp XSlope (%)	1.3
N/A	Flare Type LT	Sloped	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	5.9	Yes	Flare Slope RT (%)	2.4
N/A	Flare Traversable LT?	Yes	N/A	Flare Traversable RT?	Yes
Yes	Landing Length (in)	68.0	Yes	DWS Provided?	Yes
Yes	Landing Width (in)	48.0	Yes	DWS Contrast?	Yes
No	Landing Slope (%)	2.5	Yes	DWS Length (in)	25.5
Yes	Landing X Slope (%)	0.2	Yes	DWS Full Width?	Yes
N/A	Landing Curb? (Y/N)	No	No	DWS Offset (in)	4.0
N/A	Shared Landing?	No			
No	Gutter Ponding?	Yes	Yes	Gutter Slope (%)	4.9
Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	1.5
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	Yes
	X Walk 1 Direction	To NE		X Walk 2 Direction	To NW
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	99.0
	X Walk 1 Slope (%)	1.2		X Walk 2 Slope (%)	1.0
	X Walk 1 X Slope (%)	0.2		X Walk 2 X Slope (%)	1.0
N/A	Ramp inside XWalk1?	N/A	No	Ramp inside XWalk2?	No
	Road Slope (%)	2.3	N/A	Clear Space?	Yes
	Road X Slope (%)	0.3	N/A	Clear Space to XWalk (in)	N/A
Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
			Yes	Surface Condition? (G/P)	Good

Street 1 Name **HIGHLAND CREEK PY**  
 Stop Condition-Street 2 **None**  
 Street 2 Name **CAMBRIDGE BAY DR**  
 Stop Condition-Street 1 **StopSign**

