


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: N/A		Main Street: SUGAR_CREEK_RD		Cross Street: N/A		Location:		NE			
ADA ID: B54D5336B816		Ramp Type: Directional1		Initial Pass/Fail: Pass		Overall Compliance: No		Severity Score: 7.75			
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance							
 Street 1 NameENTRANCE Stop Condition-Street 1None Street 2 NameN/A Stop Condition-Street 2N/A				Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
				Remove & Replace Entire Ramp. Grind Gutter Lip.		N/A	Ramp Length (in)	72.5	Yes	Grade Break?	Yes
						Yes	Ramp Width (in)	59.0	No	Grade Break Slope (%)	6.9
						Yes	Ramp Slope (%)	6.0	No	Grade Break XSlope (%)	3.2
						No	Ramp XSlope (%)	2.2			
						Yes	Flare Type LT	N/A	Yes	Flare Type RT	N/A
						N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
						N/A	Flare Traversable LT?	No	N/A	Flare Traversable RT?	No
						Yes	Landing Length (in)	60.0	Yes	DWS Provided?	Yes
						Yes	Landing Width (in)	60.0	Yes	DWS Contrast?	Yes
		Yes	Landing Slope (%)	0.9	Yes	DWS Length (in)	24.0				
		Yes	Landing X Slope (%)	2.0	Yes	DWS Full Width?	Yes				
		N/A	Landing Curb? (Y/N)	N/A	Yes	DWS Offset LT (in)	1.0				
		N/A	Shared Landing?	No	Yes	DWS Offset RT (in)	55.0				
		Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	0.5				
		No	Gutter Lip Ht (in)	0.5	Yes	Gutter X Slope (%)	1.6				
		N/A	Painted X Walk1?	No		Road Slope (%)	0.0				
			X Walk 1 Direction	To SE		Road X Slope (%)	0.1				
			X Walk 1 Width (in)	N/A		Clear Space?	Yes				
			X Walk 1 Slope (%)	0.0	N/A	Clear Space to XWalk (in)	N/A				
			X Walk 1 X Slope (%)	0.1	Yes	Storm Grate/Utility Hazard?	No				
		N/A	Ramp inside XWalk1?	N/A		Storm Grate/Utility Type					
		Yes	Any Obstructions?	No			N/A				
			Obstruction Type		Yes	Surface Condition? (G/P)	Good				
					N/A	Curb Slope (%)	9.0				
		Total Cost:		\$	1800.00						

Street 1 Name	ENTRANCE
Stop Condition-Street 1	None
Street 2 Name	N/A
Stop Condition-Street 2	N/A

