


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 20184	Main Street: SOUTH_PARK_DR	Cross Street: SHARON_RD	Location:	N
ADA ID: B82F09867AE9	Ramp Type: Perp	Initial Pass/Fail: Pass	Overall Compliance: No	Severity Score: 10.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance							
	Possible Solutions:		<b>Compliance</b>			<b>Description</b>			<b>Data</b>	
	<b>Remove &amp; Replace Entire Ramp.</b>		<b>N/A</b>	Ramp Length (in)	<b>83.0</b>	<b>Yes</b>	Ramp Slope (%)	<b>6.7</b>		
			<b>Yes</b>	Ramp Width (in)	<b>48.0</b>	<b>No</b>	Ramp XSlope (%)	<b>2.3</b>		
			<b>N/A</b>	Flare Type LT	<b>Sloped</b>	<b>N/A</b>	Flare Type RT	<b>N/A</b>		
			<b>N/A</b>	Flare Slope LT (%)	<b>5.6</b>	<b>Yes</b>	Flare Slope RT (%)	<b>1.5</b>		
			<b>N/A</b>	Flare Traversable LT?	<b>No</b>	<b>N/A</b>	Flare Traversable RT?	<b>Yes</b>		
			<b>Yes</b>	Landing Length (in)	<b>68.0</b>	<b>No</b>	DWS Provided?	<b>No</b>		
			<b>Yes</b>	Landing Width (in)	<b>102.0</b>	<b>N/A</b>	DWS Contrast?	<b>No</b>		
			<b>No</b>	Landing Slope (%)	<b>3.3</b>	<b>N/A</b>	DWS Length (in)	<b>N/A</b>		
			<b>No</b>	Landing X Slope (%)	<b>3.5</b>	<b>N/A</b>	DWS Full Width?	<b>No</b>		
<p>Surveyor Notes:</p> <p><b>N/A</b></p> <p>PROW/ADA:</p> <p><b>R304.5.3, R304.2.2-Perp, R304.3.2-Para, R305</b></p>			<b>N/A</b>	Landing Curb? (Y/N)	<b>No</b>	<b>N/A</b>	DWS Offset (in)	<b>N/A</b>		
			<b>N/A</b>	Shared Landing?	<b>No</b>					
			<b>Yes</b>	Gutter Ponding?	<b>No</b>	<b>Yes</b>	Gutter Slope (%)	<b>3.0</b>		
			<b>Yes</b>	Gutter Lip Ht (in)	<b>0.0</b>	<b>Yes</b>	Gutter X Slope (%)	<b>1.7</b>		
			<b>N/A</b>	Painted X Walk1?	<b>Yes</b>	<b>N/A</b>	Painted X Walk2?	<b>N/A</b>		
				X Walk 1 Direction	<b>To SW</b>		X Walk 2 Direction	<b>N/A</b>		
			<b>N/A</b>	X Walk 1 Width (in)	<b>71.0</b>	<b>N/A</b>	X Walk 2 Width (in)	<b>N/A</b>		
				X Walk 1 Slope (%)	<b>0.0</b>		X Walk 2 Slope (%)	<b>N/A</b>		
				X Walk 1 X Slope (%)	<b>1.5</b>		X Walk 2 X Slope (%)	<b>N/A</b>		
			<b>Yes</b>	Ramp inside XWalk1?	<b>Yes</b>	<b>N/A</b>	Ramp inside XWalk2?	<b>N/A</b>		
			Road Slope (%)	<b>N/A</b>	<b>N/A</b>	Clear Space?	<b>Yes</b>			
			Road X Slope (%)	<b>N/A</b>	<b>N/A</b>	Clear Space to XWalk (in)	<b>N/A</b>			
		<b>Yes</b>	Any Obstructions?	<b>No</b>	<b>Yes</b>	Storm Grate/Utility Hazard?	<b>No</b>			
			Obstruction Type			Storm Grate/Utility Type				
					<b>N/A</b>		<b>N/A</b>			
						<b>Yes</b>	Surface Condition? (G/P)	<b>Good</b>		

