


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 5662	Main Street: KEITH_DR	Cross Street: STATESVILLE_RD	Location: NE
ADA ID: B98033126A7D	Ramp Type: Directional1	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 7.5	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	80.0	Yes	Grade Break?	Yes
	Remove & Replace Gutter.		Yes	Ramp Width (in)	76.0	Yes	Grade Break Slope (%)	3.5
			Yes	Ramp Slope (%)	4.6	Yes	Grade Break XSlope (%)	0.5
			Yes	Ramp XSlope (%)	0.2			
			Yes	Flare Type LT	N/A	Yes	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	No	N/A	Flare Traversable RT?	No
			Yes	Landing Length (in)	57.0	Yes	DWS Provided?	Yes
			Yes	Landing Width (in)	76.0	Yes	DWS Contrast?	Yes
Surveyor Notes:		Yes	Landing Slope (%)	4.7	Yes	DWS Length (in)	24.0	
N/A		Yes	Landing X Slope (%)	0.3	Yes	DWS Full Width?	Yes	
PROW/ADA:		N/A	Landing Curb? (Y/N)	No	Yes	DWS Offset LT (in)	0.0	
Not Found, R304.2.2-Perp, R304.3.2-Para, R302.7, R302.7.2, R304.5.3		N/A	Shared Landing?	No	Yes	DWS Offset RT (in)	60.0	
		No	Gutter Ponding?	Yes	Yes	Gutter Slope (%)	3.3	
		No	Gutter Lip Ht (in)	0.3	No	Gutter X Slope (%)	4.5	
		N/A	Painted X Walk1?	No		Road Slope (%)	1.0	
			X Walk 1 Direction	To S		Road X Slope (%)	3.4	
			X Walk 1 Width (in)	N/A		Clear Space?	Yes	
			X Walk 1 Slope (%)	1.0	N/A	Clear Space to XWalk (in)	N/A	
			X Walk 1 X Slope (%)	3.4	Yes	Storm Grate/Utility Hazard?	No	
		N/A	Ramp inside XWalk1?	N/A		Storm Grate/Utility Type		
		Yes	Any Obstructions?	No			N/A	
			Obstruction Type		Yes	Surface Condition? (G/P)	Good	
					N/A	Curb Slope (%)	9.3	
Street 1 Name		KEITH DR						
Stop Condition-Street 1		StopSign						
Street 2 Name		N/A						
Stop Condition-Street 2		N/A						
Total Cost:		\$ 2350.00						

