


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 2460	Main Street: CAMBRIDGE_BAY_DR	Cross Street: GASKILL_CT	Location: NW
ADA ID: BA9798175675	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	

	Possible Solutions:						
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.						
	Surveyor Notes:				Compliance	Description	Data
	N/A				Yes	Ramp Slope (%)	6.2
	PROW/ADA:				No	Ramp Width (in)	36.0
	R304.5.1				N/A	Flare Type LT	N/A
					N/A	Flare Slope LT (%)	N/A
					N/A	Flare Traversable LT?	N/A
					N/A	Flare Slope RT (%)	N/A
					N/A	Flare Traversable RT?	N/A
					N/A	DWS Provided?	N/A
					N/A	DWS Contrast?	N/A
					N/A	DWS Length (in)	N/A
					N/A	DWS Full Width?	N/A
					N/A	DWS Offset (in)	N/A
					N/A	Gutter Ponding?	N/A
					N/A	Gutter Lip Ht (in)	N/A
					No	Painted X Walk1?	No
					To S	X Walk 2 Direction	To E
					N/A	X Walk 2 Width (in)	N/A
					2.9	X Walk 2 Slope (%)	4.0
					4.4	X Walk 2 X Slope (%)	0.7
					N/A	Ramp inside XWalk2?	N/A
					N/A	Clear Space?	N/A
					4.0	Clear Space to XWalk (in)	N/A
					5.1	Storm Grate/Utility Hazard?	N/A
					N/A	Storm Grate/Utility Type	N/A
					N/A	Surface Condition? (G/P)	Good
Total Cost:		\$ 3200.00					

