

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 42864	Main Street: ALBEMARLE_RD	Cross Street: LAKE_LESLIE_LN	Location: SE
ADA ID: BCA8CE2F8D36	Ramp Type: Perp	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 29	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	55.0	Yes	Ramp Slope (%)	7.8
	Remove & Replace Gutter.		No	Ramp Width (in)	46.0	No	Ramp XSlope (%)	2.9
			N/A	Flare Type LT	Sloped	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	10.4	Yes	Flare Slope RT (%)	7.8
			N/A	Flare Traversable LT?	Yes	N/A	Flare Traversable RT?	Yes
			No	Landing Length (in)	N/A	Yes	DWS Provided?	Yes
			No	Landing Width (in)	N/A	Yes	DWS Contrast?	Yes
			No	Landing Slope (%)	N/A	Yes	DWS Length (in)	25.5
			No	Landing X Slope (%)	N/A	Yes	DWS Full Width?	Yes
Surveyor Notes:		N/A	N/A	Landing Curb? (Y/N)	No	No	DWS Offset (in)	3.0
PROW/ADA:		Not Found, R304.5.1, R304.5.3, R304.2.1, R304.2.2-Perp, R304.3.2-Para, R304.2.3, R305.2, R302.7.2		N/A	Shared Landing?	No		
			Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	3.1
			No	Gutter Lip Ht (in)	1.0	No	Gutter X Slope (%)	2.3
			N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
				X Walk 1 Direction	To N		X Walk 2 Direction	N/A
			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	5.0		X Walk 2 Slope (%)	N/A
				X Walk 1 X Slope (%)	0.6		X Walk 2 X Slope (%)	N/A
			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
				Road Slope (%)	N/A	N/A	Clear Space?	Yes
				Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
			Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
				Obstruction Type			Storm Grate/Utility Type	
						N/A		N/A
						Yes	Surface Condition? (G/P)	Good
Street 1 Name		ALBEMARLE RD						
Stop Condition-Street 2		None						
Street 2 Name		N/A						
Stop Condition-Street 1		N/A						
Total Cost:		\$ 2600.00						

