

## Access Compliance Report Public Rights-of-Way (Curb Ramps)



Intersection ID: 28184Main Street:ARDREY\_KELL\_DRCross Street:BLAKENEY\_PROFESSIONAL\_DRLocation:SWADA ID: BD72458A6471Ramp Type:PerpInitial Pass/Fail:FailOverall Compliance:NoSeverity Score:10

## **Codes/Mitigation Info/Possible Solution**

## Field Measurements/Component Compliance

Yes

Surface Condition? (G/P)

Good



Street 1 Name	BLAKENEY PROFESSIONAL DR
Stop Condition-Street 2	2 Signal
Street 2 Name	N/A
Stop Condition-Street	1 <b>N/A</b>

7/F033ible 30iulioli	r leid Measurements/Component Compilance						
Possible Solutions:	Comp	Compliance Description		Data Compliance Description		Data	
Remove & Replace Entire Ramp.	N/A	Ramp Length (in)	61.0	Yes	Ramp Slope (%)	7.0	
	No	Ramp Width (in)	46.0	No	Ramp XSlope (%)	2.3	
	N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A	
	N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A	
	N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A	
	N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A	
Surveyor Notes:	N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A	
N/A	N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A	
	N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A	
	N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
	N/A	Shared Landing?	N/A				
PROW/ADA:	N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
Not Found, R304.5.1, R304.5.3	N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	
,	N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	N/A	
•		X Walk 1 Direction	To E		X Walk 2 Direction	N/A	
	N/A	X Walk 1 Width (in)	106.0	N/A	X Walk 2 Width (in)	N/A	
		X Walk 1 Slope (%)	2.2		X Walk 2 Slope (%)	N/A	
		X Walk 1 X Slope (%)	0.9		X Walk 2 X Slope (%)	N/A	
	N/A	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A	
		Road Slope (%)	N/A	N/A	Clear Space?	N/A	
		Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A	
	N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
Total Cost: \$ 1850.00		Obstruction Type			Storm Grate/Utility Type		
			N/A			N/A	





