


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 10022370		Main Street: CAMILLA_DR		Cross Street: N/A		Location: NE			
ADA ID: C49F9FF3BE8A		Ramp Type: Directional1		Initial Pass/Fail: Pass		Overall Compliance: No		Severity Score: 0	
Codes/Mitigation Info/Possible Solution				Field Measurements/Component Compliance					
<div></div> <div>Possible Solutions: <b>Remove &amp; Replace Entire Ramp.</b></div> <div>Surveyor Notes: <b>N/A</b></div> <div>PROW/ADA: <b>R304.5.3</b></div> <div>Street 1 NameENTRANCE</div> <div>Stop Condition-Street 1StopSign</div> <div>Street 2 NameN/A</div> <div>Stop Condition-Street 2N/A</div> <div>Total Cost:\$1600.00</div>				Compliance	Description	Data	Compliance	Description	Data
				N/A	Ramp Length (in)	73.5	Yes	Grade Break?	Yes
				Yes	Ramp Width (in)	49.0	Yes	Grade Break Slope (%)	3.7
				Yes	Ramp Slope (%)	1.4	No	Grade Break XSlope (%)	2.3
				Yes	Ramp XSlope (%)	1.8			
				N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
				N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
				N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
				Yes	Landing Length (in)	60.0	Yes	DWS Provided?	Yes
				Yes	Landing Width (in)	49.0	Yes	DWS Contrast?	Yes
				Yes	Landing Slope (%)	0.1	Yes	DWS Length (in)	24.5
				Yes	Landing X Slope (%)	1.3	Yes	DWS Full Width?	Yes
				N/A	Landing Curb? (Y/N)	N/A	Yes	DWS Offset LT (in)	0.0
				N/A	Shared Landing?	No	Yes	DWS Offset RT (in)	31.0
				Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	1.0
				Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	0.4
				N/A	Painted X Walk1?	No		Road Slope (%)	0.2
					X Walk 1 Direction	To SW		Road X Slope (%)	1.5
					X Walk 1 Width (in)	N/A		Clear Space?	Yes
					X Walk 1 Slope (%)	0.2	N/A	Clear Space to XWalk (in)	N/A
					X Walk 1 X Slope (%)	1.5	Yes	Storm Grate/Utility Hazard?	No
				N/A	Ramp inside XWalk1?	N/A		Storm Grate/Utility Type	
				Yes	Any Obstructions?	No			N/A
					Obstruction Type		Yes	Surface Condition? (G/P)	Good
							N/A	Curb Slope (%)	7.5

