


Access Compliance Report

Public Rights-of-Way (Curb Ramps)

Intersection ID: 48464	Main Street: TARPWAY_RD	Cross Street: PETE_BROWN_RD	Location: SW
ADA ID: C4B78FF6C7E5	Ramp Type: Directional1	Initial Pass/Fail: Pass	Overall Compliance: No
		Severity Score: 2.5	

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance					
 Street 1 Name TARPWAY RD Stop Condition-Street 1 StopSign Street 2 Name N/A Stop Condition-Street 2 N/A	Possible Solutions:	Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Entire Ramp.	N/A	Ramp Length (in)	48.0	No	Grade Break?	No
		Yes	Ramp Width (in)	73.0	N/A	Grade Break Slope (%)	N/A
		Yes	Ramp Slope (%)	6.2	N/A	Grade Break XSlope (%)	N/A
		Yes	Ramp XSlope (%)	1.9			
		Yes	Flare Type LT	N/A	Yes	Flare Type RT	N/A
		N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
		N/A	Flare Traversable LT?	No	N/A	Flare Traversable RT?	No
		Yes	Landing Length (in)	71.0	Yes	DWS Provided?	Yes
		Yes	Landing Width (in)	71.0	Yes	DWS Contrast?	Yes
Surveyor Notes: N/A PROW/ADA: R304.5.2, R305.1.4, R305.2		Yes	Landing Slope (%)	1.2	Yes	DWS Length (in)	24.0
		Yes	Landing X Slope (%)	0.8	No	DWS Full Width?	No
		N/A	Landing Curb? (Y/N)	N/A	Yes	DWS Offset LT (in)	34.5
		N/A	Shared Landing?	No	No	DWS Offset RT (in)	5.5
		Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	0.1
		Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	1.9
		N/A	Painted X Walk1?	No		Road Slope (%)	1.3
			X Walk 1 Direction	To E		Road X Slope (%)	3.7
			X Walk 1 Width (in)	N/A		Clear Space?	Yes
			X Walk 1 Slope (%)	1.3	N/A	Clear Space to XWalk (in)	N/A
Total Cost: \$ 1600.00			X Walk 1 X Slope (%)	3.7	Yes	Storm Grate/Utility Hazard?	No
		N/A	Ramp inside XWalk1?	N/A		Storm Grate/Utility Type	
		Yes	Any Obstructions?	No			N/A
			Obstruction Type		Yes	Surface Condition? (G/P)	Good
					N/A	Curb Slope (%)	N/A

