

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 10162	Main Street: E_SUGAR_CREEK_RD	Cross Street: THE_PLAZA	Location: NE
ADA ID: C8F8FAC24ED2	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 28.75

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Possible Solutions:

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Surveyor Notes:

N/A

PROW/ADA:

Not Found, R304.2.2, R302.7

Total Cost: \$ 3200.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	25.5	No	Ramp Slope (%)	9.9
Yes	Ramp Width (in)	48.0	Yes	Ramp XSlope (%)	3.2
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	Yes
	X Walk 1 Direction	To SW		X Walk 2 Direction	To SE
N/A	X Walk 1 Width (in)	102.5	N/A	X Walk 2 Width (in)	105.0
	X Walk 1 Slope (%)	2.1		X Walk 2 Slope (%)	3.9
	X Walk 1 X Slope (%)	1.3		X Walk 2 X Slope (%)	1.5
N/A	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	Yes
	Road Slope (%)	3.3	N/A	Clear Space?	N/A
	Road X Slope (%)	2.5	N/A	Clear Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
		No		Surface Condition? (G/P)	Poor

Street 1 Name **E SUGAR CREEK RD**
 Stop Condition-Street 2 **Signal**
 Street 2 Name **THE PLAZA**
 Stop Condition-Street 1 **Signal**

