


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 49391	Main Street: GELBRAY_CT	Cross Street: AUBRAC_LN	Location: NE
ADA ID: CAD6B2C455A5	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 21.25

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance							
	Possible Solutions:			Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.	N/A	Ramp Length (in)	70.5	Yes	Ramp Slope (%)	5.7		
		No	Ramp Width (in)	47.5	No	Ramp XSlope (%)	5.2		
		N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A		
	N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A			
	N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A			
	N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A			
	N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A			
	N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A			
	N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A			
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A				
Surveyor Notes:	N/A	N/A	Shared Landing?	N/A					
		N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A		
		N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A		
	PROW/ADA:	Not Found, R304.5.1, R304.5.3	N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No	
				X Walk 1 Direction	To W		X Walk 2 Direction	To S	
			N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A	
				X Walk 1 Slope (%)	0.9		X Walk 2 Slope (%)	4.6	
				X Walk 1 X Slope (%)	3.1		X Walk 2 X Slope (%)	2.1	
			N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A	
				Road Slope (%)	5.1	N/A	Clear Space?	N/A	
Total Cost:	\$ 3200.00		Road X Slope (%)	0.0	N/A	Clear Space to XWalk (in)	N/A		
		N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A		
			Obstruction Type			Storm Grate/Utility Type			
				N/A		N/A			
					Yes	Surface Condition? (G/P)	Good		

Street 1 Name	GELBRAY CT
Stop Condition-Street 2	StopSign
Street 2 Name	AUBRAC LN
Stop Condition-Street 1	None

Total Cost: \$ 3200.00

