

Access Compliance Report Public Rights-of-Way (Curb Ramps)



N/A

N/A

N/A

Good

15.7

Intersection ID: 42785 Main Street: CALDWELL_RD Cross Street: OLD_STONE_CROSSING_DR Location: SE

ADA ID: CCF08345F564 Ramp Type: Combination1 Initial Pass/Fail: Fail Overall Compliance: No Severity Score: 46.25

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Street 1 Name
StopSign
Stop Condition-Street 1
OLD STONE CROSSING DR
Street 2 Name
N/A
Stop Condition-Street 2
N/A

Possible Solutions:

Remove & Replace Entire Ramp.

Surveyor Notes:

RT RP < 5%

PROW/ADA:

Not Found, R304.5.1, R304.5.3, R304.3.2

Total Cost: \$ 1800.00



N/A

Yes

Storm Grate/Utility Hazard?

Storm Grate/Utility Type

Surface Condition? (G/P)

Curb Slope (%)





