

Access Compliance Report

Public Rights-of-Way (Curb Ramps)

Intersection ID: 11153	Main Street: E_W_T_HARRIS_BV	Cross Street: N_SHARON_AMITY_RD	Location: SW
ADA ID: CF437A2F9039	Ramp Type: Combination2	Initial Pass/Fail: Fail	Overall Compliance: No Severity Score: 43.75

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Possible Solutions:

Remove & Replace Entire Ramp.

Surveyor Notes:

LT RP < 5%

PROW/ADA:

**Not Found, R304.5.1, R304.2.2,
R304.3.2, R304.5.3**

Total Cost: \$ 1600.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length LT (in)	67.5	N/A	Ramp Length RT (in)	57.0
N/A	Ramp Width LT (in)	34.0	No	Ramp Width RT (in)	34.0
N/A	Ramp Slope LT (%)	0.2	No	Ramp Slope RT (%)	9.3
N/A	Ramp XSlope LT (%)	1.5	No	Ramp XSlope RT (%)	4.0
N/A	Ramp Length (in)	60.0	No	Ramp Slope (%)	14.1
Yes	Ramp Width (in)	48.0	Yes	Ramp XSlope (%)	4.0
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	N/A
	X Walk 1 Direction	To SE		X Walk 2 Direction	N/A
	X Walk 1 Width (in)	110.0		X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	2.4		X Walk 2 Slope (%)	N/A
	X Walk 1 X Slope (%)	4.9		X Walk 2 X Slope (%)	N/A
N/A	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	N/A		Clear Space?	N/A
	Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
			N/A	Any Obstruction?	N/A
				Obstruction Type	N/A
			N/A	Storm Grate/Utility Hazard?	N/A
				Storm Grate/Utility Type	N/A
Yes	Surface Condition? (G/P)	Good			
	Curb Slope (%)	25.1			

Street 1 Name	Signal
Stop Condition-Street 1	N SHARON AMITY RD
Street 2 Name	N/A
Stop Condition-Street 2	N/A

