


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

|                        |                            |                         |                        |
|------------------------|----------------------------|-------------------------|------------------------|
| Intersection ID: 46188 | Main Street: SEVEN_OAKS_DR | Cross Street: YAUPON_RD | Location: SE           |
| ADA ID: D03F7E1A571D   | Ramp Type: PerpDiag        | Initial Pass/Fail: Fail | Overall Compliance: No |
|                        |                            |                         | Severity Score: 13.75  |

| Codes/Mitigation Info/Possible Solution  |  |    | Field Measurements/Component Compliance |                       |      |            |                          |      |
|--|--|----|---|-----------------------|------|------------|--------------------------|------|
|      | Possible Solutions:  |    | Compliance                              | Description           | Data | Compliance | Description              | Data |
|  | Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent. |    | N/A                                     | Ramp Length (in)      | 74.5 | No         | Ramp Slope (%)           | 9.8  |
|  |  |    | Yes                                     | Ramp Width (in)       | 48.0 | No         | Ramp XSlope (%)          | 2.3  |
|  |  |    | N/A                                     | Flare Type LT         | N/A  | N/A        | Flare Type RT            | N/A  |
|  |  |    | N/A                                     | Flare Slope LT (%)    | N/A  | N/A        | Flare Slope RT (%)       | N/A  |
|  |  |    | N/A                                     | Flare Traversable LT? | N/A  | N/A        | Flare Traversable RT?    | N/A  |
|  |  |    | N/A                                     | Landing Length (in)   | N/A  | N/A        | DWS Provided?            | N/A  |
|  |  |    | N/A                                     | Landing Width (in)    | N/A  | N/A        | DWS Contrast?            | N/A  |
|  |  |    | N/A                                     | Landing Slope (%)     | N/A  | N/A        | DWS Length (in)          | N/A  |
|  |  |    | N/A                                     | Landing X Slope (%)   | N/A  | N/A        | DWS Full Width?          | N/A  |
| Street 1 Name<br>Stop Condition-Street 2<br>Street 2 Name<br>Stop Condition-Street 1 | SEVEN OAKS DR  |    | N/A                                     | Landing Curb? (Y/N)   | N/A  | N/A        | DWS Offset (in)          | N/A  |
|  | YAUPON RD  |    | N/A                                     | Shared Landing?       | N/A  |            |                          |      |
|  | StopSign   |    | N/A                                     | Gutter Ponding?       | N/A  | N/A        | Gutter Slope (%)         | N/A  |
|  | SEVEN OAKS DR  |    | N/A                                     | Gutter Lip Ht (in)    | 1.0  | N/A        | Gutter X Slope (%)       | N/A  |
|  | None   |    | N/A                                     | Painted X Walk1?      | No   | N/A        | Painted X Walk2?         | No   |
|  |  |    |   | X Walk 1 Direction    | To N |            | X Walk 2 Direction       | To W |
|  |  |    | N/A                                     | X Walk 1 Width (in)   | N/A  | N/A        | X Walk 2 Width (in)      | N/A  |
|  |  |    |   | X Walk 1 Slope (%)    | 1.7  |            | X Walk 2 Slope (%)       | 4.4  |
|  |  |    |   | X Walk 1 X Slope (%)  | 1.7  |            | X Walk 2 X Slope (%)     | 1.7  |
|  |  |    | N/A                                     | Ramp inside XWalk1?   | N/A  | N/A        | Ramp inside XWalk2?      | N/A  |
| Total Cost:  |  | \$ | 3200.00                                 |                       |      | N/A        |                          | N/A  |
|  |  |    |   |                       |      | Yes        | Surface Condition? (G/P) | Good |

|                         |               |
|-------------------------|---------------|
| Street 1 Name           | YAUPON RD     |
| Stop Condition-Street 2 | StopSign      |
| Street 2 Name           | SEVEN OAKS DR |
| Stop Condition-Street 1 | None          |

