


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 8569	Main Street: PENNY_WY	Cross Street: W_SUGAR_CREEK_RD	Location: SE
ADA ID: D3FD14E6FBD4	Ramp Type: ParaDiag	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 31.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance		
	Possible Solutions:		<b>Compliance</b>	<b>Description</b>	<b>Data</b>
	<b>Remove &amp; Replace Curb Ramp With Two New Directional Ramps or Equivalent.</b>		<b>N/A</b>	Ramp Length LT (in)	<b>53.0</b>
			<b>No</b>	Ramp Width LT (in)	<b>34.5</b>
			<b>Yes</b>	Ramp Slope LT (%)	<b>1.0</b>
			<b>Yes</b>	Ramp XSlope LT (%)	<b>0.9</b>
			<b>N/A</b>	Landing Length (in)	<b>N/A</b>
			<b>N/A</b>	Landing Width (in)	<b>N/A</b>
			<b>N/A</b>	Landing Slope (%)	<b>N/A</b>
			<b>N/A</b>	Landing X Slope (%)	<b>N/A</b>
			<b>N/A</b>	Landing Curb? (Y/N)	<b>N/A</b>
			<b>N/A</b>	Shared Landing?	<b>N/A</b>
			<b>N/A</b>	Gutter Ponding?	<b>N/A</b>
			<b>N/A</b>	Gutter Lip Ht (in)	<b>N/A</b>
			<b>N/A</b>	Painted X Walk1?	<b>No</b>
				X Walk 1 Direction	<b>To N</b>
			<b>N/A</b>	X Walk 1 Width (in)	<b>N/A</b>
				X Walk 1 Slope (%)	<b>3.1</b>
				X Walk 1 X Slope (%)	<b>4.9</b>
			<b>N/A</b>	Ramp inside XWalk1?	<b>N/A</b>
				Road Slope (%)	<b>2.6</b>
				Road X Slope (%)	<b>6.6</b>
			<b>N/A</b>	Any Obstructions?	<b>N/A</b>
				Obstruction Type	
			<b>N/A</b>		<b>N/A</b>
			<b>Yes</b>	Surface Condition? (G/P)	<b>Good</b>
			<b>N/A</b>	Curb Slope (%)	<b>19.0</b>
Surveyor Notes:					
<b>LT RP SL &lt; 5%. MEDIAN ACROSS W SUGAR CREEK RD</b>					
PROW/ADA:					
<b>R304.5.1, R304.3.2, R304.5.3</b>					
Total Cost:					
\$ 3200.00					

Street 1 Name	PENNY WY
Stop Condition-Street 1	StopSign
Street 2 Name	W SUGAR CREEK RD
Stop Condition-Street 2	None

