


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 30009	Main Street: BACKWATER_DR	Cross Street: OLD_CAROLINA_DR	Location: W
ADA ID: D42670816E8A	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 8.75	

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance			
 Street 1 Name BACKWATER DR Stop Condition-Street 2 StopSign Street 2 Name OLD CAROLINA DR Stop Condition-Street 1 StopSign	Possible Solutions:	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.			
	Surveyor Notes:	N/A			
	PROW/ADA:	Not Found, R304.5.1			
	Total Cost:	\$ 3200.00			
			Compliance	Description	Data
			Yes	Ramp Length (in)	59.5
			No	Ramp Width (in)	45.0
			N/A	Flare Type LT	N/A
			N/A	Flare Slope LT (%)	N/A
			N/A	Flare Traversable LT?	N/A
			N/A	Landing Length (in)	N/A
			N/A	Landing Width (in)	N/A
			N/A	Landing Slope (%)	N/A
			N/A	Landing X Slope (%)	N/A
			N/A	Landing Curb? (Y/N)	N/A
			N/A	Shared Landing?	N/A
			N/A	Gutter Ponding?	N/A
			N/A	Gutter Lip Ht (in)	N/A
			N/A	Painted X Walk1?	No
			N/A	X Walk 1 Direction	To SE
			N/A	X Walk 1 Width (in)	N/A
			N/A	X Walk 1 Slope (%)	3.1
			N/A	X Walk 1 X Slope (%)	2.2
			N/A	Ramp inside XWalk1?	N/A
			N/A	Road Slope (%)	0.4
			N/A	Road X Slope (%)	5.4
			N/A	Any Obstructions?	N/A
			N/A	Obstruction Type	N/A
			N/A	Surface Condition? (G/P)	Good

