

Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: N/A	Main Street: BRADSTREET COMMONS WY	Cross Street: DELUCA DR	Location: W
ADA ID: D51A4DE19392	Ramp Type: Combination2Diag	Initial Pass/Fail: Fail	Overall Compliance: No
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	

	Possible Solutions:		Compliance		Description		Data	Compliance		Description		Data
	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		N/A		Ramp Length LT (in)		47.0	N/A		Ramp Length RT (in)		59.0
			No		Ramp Width LT (in)		46.0	No		Ramp Width RT (in)		46.5
			Yes		Ramp Slope LT (%)		5.0	Yes		Ramp Slope RT (%)		2.7
			Yes		Ramp XSlope LT (%)		1.0	Yes		Ramp XSlope RT (%)		0.7
			N/A		Ramp Length (in)		48.5	Yes		Ramp Slope (%)		7.4
			No		Ramp Width (in)		46.0	No		Ramp XSlope (%)		4.4
			N/A		Flare Type LT		N/A	N/A		Flare Type RT		N/A
			N/A		Flare Slope LT (%)		N/A	N/A		Flare Slope RT (%)		N/A
			N/A		Flare Traversable LT?		N/A	N/A		Flare Traversable RT?		N/A
Surveyor Notes: N/A	PROW/ADA:		N/A		Landing Length (in)		N/A	N/A		DWS Provided?		N/A
	Not Found, R304.5.1, R304.5.1, R304.5.3		N/A		Landing Width (in)		N/A	N/A		DWS Contrast?		N/A
			N/A		Landing Slope (%)		N/A	N/A		DWS Length (in)		N/A
			N/A		Landing X Slope (%)		N/A	N/A		DWS Full Width?		N/A
			N/A		Landing Curb? (Y/N)		N/A	N/A		DWS Offset (in)		N/A
			N/A		Shared Landing?		N/A					
			N/A		Gutter Ponding?		N/A	N/A		Gutter Slope (%)		N/A
			N/A		Gutter Lip Ht (in)		N/A	N/A		Gutter X Slope (%)		N/A
			N/A		Painted X Walk1?		No	N/A		Painted X Walk2?		No
					X Walk 1 Direction		To SE			X Walk 2 Direction		To NE
Street 1 Name Stop Condition-Street 1 Street 2 Name Stop Condition-Street 2	StopSign DELUCA DR StopSign BRADSTREET COMMONS WY				X Walk 1 Width (in)		N/A			X Walk 2 Width (in)		N/A
					X Walk 1 Slope (%)		1.2			X Walk 2 Slope (%)		0.7
					X Walk 1 X Slope (%)		0.9			X Walk 2 X Slope (%)		2.3
			N/A		Ramp inside XWalk1?		N/A	N/A		Ramp inside XWalk2?		N/A
					Road Slope (%)		1.5			Clear Space?		N/A
					Road X Slope (%)		0.3	N/A		Clear Space to XWalk (in)		N/A
								N/A		Any Obstruction?		N/A
										Obstruction Type		N/A
  												