


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 16843	Main Street: OLD_PINEVILLE_RD	Cross Street: NATIONS_CROSSING_RD	Location: NW
ADA ID: D59F747F4556	Ramp Type: PerpDiag	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 12.5	

Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance															
	Possible Solutions:	Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.		Compliance	Description	Data	Compliance	Description	Data								
	Surveyor Notes:	N/A	PROW/ADA:	Not Found, R304.5.3	N/A	Ramp Length (in)	47.0	Yes	Ramp Slope (%)	6.1							
					Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	5.5							
					N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A							
					N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A							
					N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A							
	Street 1 Name	NATIONS CROSSING RD	Stop Condition-Street 2	StopSign	Street 2 Name	OLD PINEVILLE RD	Stop Condition-Street 1	None	Total Cost:	\$	3200.00	N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
												N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
												N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
												N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A												Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A	
N/A												Shared Landing?	N/A				
N/A												Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A	
N/A												Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A	
N/A												Painted X Walk1?	No	N/A	Painted X Walk2?	No	
												X Walk 1 Direction	To SW		X Walk 2 Direction	To E	
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A												
	X Walk 1 Slope (%)	0.9		X Walk 2 Slope (%)	4.7												
	X Walk 1 X Slope (%)	4.4		X Walk 2 X Slope (%)	0.5												
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A												
	Road Slope (%)	3.1	N/A	Clear Space?	N/A												
	Road X Slope (%)	3.1	N/A	Clear Space to XWalk (in)	N/A												
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A												
	Obstruction Type			Storm Grate/Utility Type													
			N/A		N/A												
			Yes	Surface Condition? (G/P)	Good												

