


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 42482	Main Street: BLAKENEY GREENS BV	Cross Street: REA RD	Location: W
ADA ID: D8BFACFFF041	Ramp Type: PerpDiag	Initial Pass/Fail: Pass	Overall Compliance: No
Severity Score: 12.75			
Codes/Mitigation Info/Possible Solution		Field Measurements/Component Compliance	



Possible Solutions:

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Surveyor Notes:

N/A

PROW/ADA:

Not Found, R304.2.2-Perp, R304.3.2-Para, R304.2.3, R305

Total Cost: \$ 3200.00

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	73.0	Yes	Ramp Slope (%)	7.0
Yes	Ramp Width (in)	52.0	Yes	Ramp XSlope (%)	2.4
N/A	Flare Type LT	Sloped	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	2.2	No	Flare Slope RT (%)	10.3
N/A	Flare Traversable LT?	Yes	N/A	Flare Traversable RT?	Yes
Yes	Landing Length (in)	58.0	No	DWS Provided?	No
Yes	Landing Width (in)	52.0	N/A	DWS Contrast?	No
No	Landing Slope (%)	3.2	N/A	DWS Length (in)	N/A
Yes	Landing X Slope (%)	1.1	N/A	DWS Full Width?	No
N/A	Landing Curb? (Y/N)	No	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	No			
Yes	Gutter Ponding?	No	Yes	Gutter Slope (%)	2.4
Yes	Gutter Lip Ht (in)	0.0	Yes	Gutter X Slope (%)	3.6
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	No
	X Walk 1 Direction	To SE		X Walk 2 Direction	To NE
N/A	X Walk 1 Width (in)	N/A	N/A	X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	2.1		X Walk 2 Slope (%)	4.5
	X Walk 1 X Slope (%)	2.3		X Walk 2 X Slope (%)	2.1
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	4.0	N/A	Clear Space?	Yes
	Road X Slope (%)	0.1	N/A	Clear Space to XWalk (in)	N/A
Yes	Any Obstructions?	No	Yes	Storm Grate/Utility Hazard?	No
	Obstruction Type			Storm Grate/Utility Type	
		N/A			N/A
		Yes	Yes	Surface Condition? (G/P)	Good

Street 1 Name **BLAKENEY GREENS BV**
 Stop Condition-Street 2 **Signal**
 Street 2 Name **REA RD**
 Stop Condition-Street 1 **Signal**

