


# Access Compliance Report

## Public Rights-of-Way

### (Curb Ramps)

Intersection ID: 52102	Main Street: TANK_FARM_RD	Cross Street: FRED_D_ALEXANDER_BV	Location: S
ADA ID: DAD3F9A6FD3B	Ramp Type: Perp	Initial Pass/Fail: Fail	Overall Compliance: No
			Severity Score: 1.25

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	124.0	Yes	Ramp Slope (%)	7.0
			Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	4.7
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
Surveyor Notes:		N/A	N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
PROW/ADA:		Not Found, R304.5.3	N/A	Shared Landing?	N/A	N/A	Gutter Slope (%)	N/A
			N/A	Gutter Ponding?	N/A	N/A	Gutter X Slope (%)	N/A
			N/A	Gutter Lip Ht (in)	N/A	N/A	Painted X Walk2?	N/A
			N/A	Painted X Walk1?	Yes	N/A	X Walk 2 Direction	N/A
				X Walk 1 Direction	To N		X Walk 2 Width (in)	N/A
			N/A	X Walk 1 Width (in)	111.0	N/A	X Walk 2 Slope (%)	N/A
				X Walk 1 Slope (%)	5.2		X Walk 2 X Slope (%)	N/A
				X Walk 1 X Slope (%)	0.5		Ramp inside XWalk2?	N/A
			N/A	Ramp inside XWalk1?	Yes	N/A	Clear Space?	N/A
				Road Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A
				Road X Slope (%)	N/A	N/A	Storm Grate/Utility Hazard?	N/A
			N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Type	
				Obstruction Type				
					N/A			N/A
						Yes	Surface Condition? (G/P)	Good
Total Cost:		\$ 1850.00						
Street 1 Name		TANK FARM RD						
Stop Condition-Street 2		StopSign						
Street 2 Name		N/A						
Stop Condition-Street 1		N/A						

