Access Compliance Report
Public Rights-of-Way
(Curb Ramps)

Intersection ID: 10024384	**Main Street: CRESTVIEW_DR**	**Cross Street: N/A**		**Location:** N
ADA ID: DB145610207C	**Ramp Type: BlendTrans1**	**Initial Pass/Fail: Fail**	**Overall Compliance: No**	**Severity Score:** 10

Codes/Mitigation Info/Possible Solution	Field Measurements/Component Compliance

CRESTVIEW_DR

Possible Solutions:

Remove & Replace Curb Ramp With Two New Directional Ramps or Equivalent.

Surveyor Notes:

NO RT SW

PROW/ADA:

Not Found, R304.5.1

Total Cost: $ 3200.00

Street 1 Name	**CRESTVIEW DR**
Stop Condition-Street 1	**None**
Street 2 Name	**N/A**
Stop Condition-Street 2	**N/A**

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	49.0	Yes	BlendTrans Slope (%)	2.3
No	Ramp Width (in)	47.5	Yes	BlendTrans XSlope (%)	2.6
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
N/A	Shared Landing?	N/A			
N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	No	N/A	Painted X Walk2?	N/A
	X Walk 1 Direction	To S		X Walk 2 Direction	N/A
	X Walk 1 Width (in)	N/A		X Walk 2 Width (in)	N/A
	X Walk 1 Slope (%)	5.4		X Walk 2 Slope (%)	N/A
	X Walk 1 X Slope (%)	3.1		X Walk 2 X Slope (%)	N/A
N/A	Ramp inside XWalk1?	N/A	N/A	Ramp inside XWalk2?	N/A
	Road Slope (%)	3.1		Clear Space?	N/A
	Road X Slope (%)	5.4	N/A	Clear Space to XWalk (in)	N/A
N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A
	Obstruction Type			Storm Grate/Utility Type	
N/A					N/A
			Yes	Surface Condition? (G/P)	Good
			No	Curb Slope (%)	14.7