

Access Compliance Report


Public Rights-of-Way

(Curb Ramps)

Intersection ID: 3942	Main Street: BROWNE'S_FERRY_RD	Cross Street: KINSMORE_LN	Location:	N
ADA ID: E038177C0251	Ramp Type: Directional1	Initial Pass/Fail: Fail	Overall Compliance: No	Severity Score: 25

Codes/Mitigation Info/Possible Solution

Field Measurements/Component Compliance



Possible Solutions:

Remove & Replace Entire Ramp.

Surveyor Notes:

N/A

PROW/ADA:

R304.2.2

Compliance	Description	Data	Compliance	Description	Data
N/A	Ramp Length (in)	51.0	N/A	Grade Break?	N/A
Yes	Ramp Width (in)	49.0	N/A	Grade Break Slope (%)	0.0
No	Ramp Slope (%)	12.5	N/A	Grade Break XSlope (%)	0.0
Yes	Ramp XSlope (%)	1.8			
N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	0.0
N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
N/A	Landing Length (in)	0.0	N/A	DWS Provided?	N/A
N/A	Landing Width (in)	0.0	N/A	DWS Contrast?	N/A
N/A	Landing Slope (%)	0.0	N/A	DWS Length (in)	N/A
N/A	Landing X Slope (%)	0.0	N/A	DWS Full Width?	N/A
N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset LT (in)	N/A
N/A	Shared Landing?	N/A	N/A	DWS Offset RT (in)	N/A
N/A	Gutter Ponding?	0.0	N/A	Gutter Slope (%)	N/A
N/A	Gutter Lip Ht (in)	0.0	N/A	Gutter X Slope (%)	N/A
N/A	Painted X Walk1?	No		Road Slope (%)	2.6
	X Walk 1 Direction	To SW		Road X Slope (%)	8.8
	X Walk 1 Width (in)	N/A		Clear Space?	N/A
	X Walk 1 Slope (%)	2.6	N/A	Clear Space to XWalk (in)	N/A
	X Walk 1 X Slope (%)	8.8	N/A	Storm Grate/Utility Hazard?	N/A
N/A	Ramp inside XWalk1?	N/A		Storm Grate/Utility Type	
N/A	Any Obstructions?	N/A			N/A
	Obstruction Type		Yes	Surface Condition? (G/P)	Good
			N/A	Curb Slope (%)	18.2

Total Cost: \$ 1600.00

Street 1 Name	KINSMORE LN
Stop Condition-Street 1	StopSign
Street 2 Name	N/A
Stop Condition-Street 2	N/A

