


Access Compliance Report

Public Rights-of-Way

(Curb Ramps)

Intersection ID: 19953	Main Street: ARCHDALE_DR	Cross Street: OLD_PINEVILLE_RD	Location: SE
ADA ID: E0D829AFC547	Ramp Type: IslandPerp	Initial Pass/Fail: Fail	Overall Compliance: No
		Severity Score: 12.5	

Codes/Mitigation Info/Possible Solution			Field Measurements/Component Compliance					
	Possible Solutions:		Compliance	Description	Data	Compliance	Description	Data
	Remove & Replace Entire Ramp.		N/A	Ramp Length (in)	31.5	Yes	Ramp Slope (%)	5.6
			Yes	Ramp Width (in)	48.0	No	Ramp XSlope (%)	6.8
			N/A	Flare Type LT	N/A	N/A	Flare Type RT	N/A
			N/A	Flare Slope LT (%)	N/A	N/A	Flare Slope RT (%)	N/A
			N/A	Flare Traversable LT?	N/A	N/A	Flare Traversable RT?	N/A
			N/A	Landing Length (in)	N/A	N/A	DWS Provided?	N/A
			N/A	Landing Width (in)	N/A	N/A	DWS Contrast?	N/A
			N/A	Landing Slope (%)	N/A	N/A	DWS Length (in)	N/A
			N/A	Landing X Slope (%)	N/A	N/A	DWS Full Width?	N/A
<p>Surveyor Notes:</p> <p>N/A</p>	PROW/ADA:		N/A	Landing Curb? (Y/N)	N/A	N/A	DWS Offset (in)	N/A
	Not Found, R304.5.3		N/A	Shared Landing?	N/A			
			N/A	Gutter Ponding?	N/A	N/A	Gutter Slope (%)	N/A
			N/A	Gutter Lip Ht (in)	N/A	N/A	Gutter X Slope (%)	N/A
			N/A	Painted X Walk1?	Yes	N/A	Painted X Walk2?	N/A
				X Walk 1 Direction	To NE		X Walk 2 Direction	N/A
			N/A	X Walk 1 Width (in)	114.0	N/A	X Walk 2 Width (in)	N/A
				X Walk 1 Slope (%)	4.9		X Walk 2 Slope (%)	N/A
				X Walk 1 X Slope (%)	2.6		X Walk 2 X Slope (%)	N/A
			N/A	Ramp inside XWalk1?	Yes	N/A	Ramp inside XWalk2?	N/A
			Road Slope (%)	N/A	N/A	Clear Space?	N/A	
			Road X Slope (%)	N/A	N/A	Clear Space to XWalk (in)	N/A	
		N/A	Any Obstructions?	N/A	N/A	Storm Grate/Utility Hazard?	N/A	
			Obstruction Type			Storm Grate/Utility Type		
				N/A			N/A	
					Yes	Surface Condition? (G/P)	Good	
Street 1 Name		ARCHDALE DR						
Stop Condition-Street 2		Signal						
Street 2 Name		N/A						
Stop Condition-Street 1		N/A						
Total Cost:		\$ 3400.00						

Total Cost: \$ 3400.00

